

Source Water Protection Plan

Kanawha Falls Public Service District

PWSID WV3301037

Fayette County

April 2016

Prepared by:

Tetra Tech, Inc.

803 Quarrier Street, Suite 400

Charleston, WV 25314

In cooperation with Kanawha Falls PSD



This page is intentionally blank.

Preparer's Name

Title of Preparer

Name of Contractor/Consultant

I certify the information in the source water protection plan is complete and accurate to the best of my knowledge.

Signature of responsible party or designee authorized to sign for water utility:

Print Name of Authorizing Signatory:

Title of Authorizing Signatory:

Date of Submission:

This page is intentionally blank.

TABLE OF CONTENTS

| | |
|---|-----------|
| 1.0 PURPOSE..... | 1 |
| 1.1 What are the benefits of preparing a Source Water Protection Plan? | 1 |
| 2.0 BACKGROUND: WV SOURCE WATER ASSESSMENT AND PROTECTION PROGRAM..... | 2 |
| 3.0 STATE REGULATORY REQUIREMENTS | 3 |
| 4.0 SYSTEM INFORMATION | 4 |
| 5.0 WATER TREATMENT AND STORAGE | 5 |
| 6.0 DELINEATIONS..... | 7 |
| 7.0 PROTECTION TEAM..... | 9 |
| 8.0 POTENTIAL SOURCES OF SIGNIFICANT CONTAMINATION | 11 |
| 8.1 Confidentiality of PSSCs..... | 11 |
| 8.2 Local and Regional PSSCs | 11 |
| 8.3 Prioritization of Threats and Management Strategies | 13 |
| 9.0 IMPLEMENTATION PLAN FOR MANAGEMENT STRATEGIES | 14 |
| 10.0 EDUCATION AND OUTREACH STRATEGIES..... | 18 |
| 11.0 CONTINGENCY PLAN | 21 |
| 11.1 Response Networks and Communication | 21 |
| 11.2 Operation During Loss of Power..... | 22 |
| 11.3 Future Water Supply Needs | 23 |
| 11.4 Water Loss Calculation..... | 24 |
| 11.5 Early Warning Monitoring System | 25 |
| 12.0 SINGLE SOURCE FEASIBILITY STUDY | 28 |
| 13.0 COMMUNICATION PLAN | 29 |
| 14.0 EMERGENCY RESPONSE SHORT FORM..... | 30 |
| 15.0 CONCLUSION | 31 |

LIST OF TABLES

| | |
|--|----|
| Table 1. Population Served by Kanawha Falls PSD | 4 |
| Table 2. Kanawha Falls PSD Water Treatment Information | 5 |
| Table 3. Kanawha Falls PSD Surface Water Sources | 6 |
| Table 4. Kanawha Falls PSD Groundwater Sources | 6 |
| Table 5. Watershed Delineation Information | 8 |
| Table 6. Protection Team Member and Contact Information | 10 |
| Table 7. Locally Identified Potential Sources of Significant Contamination | 12 |
| Table 8. Priority PSSCs or Critical Areas | 15 |
| Table 9. Priority PSSC Management Strategies | 15 |
| Table 10. Education and Outreach Implementation Plan | 19 |
| Table 11. Kanawha Falls PSD Water Shortage Response Capability | 21 |
| Table 12. Generator Capacity | 22 |
| Table 13. Future Water Supply Needs for Kanawha Falls PSD | 24 |
| Table 14. Water Loss Information | 25 |
| Table 15. Early Warning Monitoring System Capabilities | 26 |

APPENDICES

- Appendix A. Figures
- Appendix B. Early Warning Monitoring System Forms
- Appendix C. Communication Plan Template
- Appendix D. Single Source Feasibility Study
- Appendix E. Supporting Documentation

SOURCE WATER PROGRAM ACRONYMS

| | |
|-----------------|--|
| AST | Aboveground Storage Tank |
| BMP | Best Management Practices |
| ERP | Emergency Response Plan |
| GWUDI | Ground Water Under the Direct Influence of Surface Water |
| LEPC | Local Emergency Planning Committee |
| OEHS/EED | Office of Environmental Health Services/Environmental Engineering Division |
| PE | Professional Engineer |
| PSSCs | Potential Source of Significant Contamination |
| PWSU | Public Water System Utility |
| RAIN | River Alert Information Network |
| RPDC | Regional Planning and Development Council |
| SDWA | Safe Drinking Water Act |
| SWAP | Source Water Assessment and Protection |
| SWAPP | Source Water Assessment and Protection Program |
| SWP | Source Water Protection |
| SWPA | Source Water Protection Area |
| SWPP | Source Water Protection Plan |
| WARN | Water/Wastewater Agency Response Network |
| WHPA | Wellhead Protection Area |
| WHPP | Wellhead Protection Program |
| WSDA | Watershed Delineation Area |
| WVBPH | West Virginia Bureau for Public Health |
| WVDEP | West Virginia Department of Environmental Protection |
| WVDHHR | West Virginia Department of Health and Human Resources |
| WVDHSEM | West Virginia Division of Homeland Security and Emergency Management |
| ZCC | Zone of Critical Concern |
| ZPC | Zone of Peripheral Concern |

1.0 PURPOSE

The goal of the West Virginia Bureau of Public Health (WVBPH) source water assessment and protection (SWAP) program is to prevent degradation of source waters which may preclude present and future uses of drinking water supplies to provide safe water in sufficient quantity to users. The most efficient way to accomplish this goal is to encourage and oversee source water protection on a local level. Many aspects of source water protection may be best addressed by engaging local stakeholders.

The intent of this document is to describe what Kanawha Falls Public Service District (PSD) has done, is currently doing, and plans to do to protect its source of drinking water. Although this water system treats the water to meet federal and state drinking water standards, conventional treatment does not fully eradicate all potential contaminants, and treatment that goes beyond conventional methods is often very expensive. By completing this plan, Kanawha Falls PSD acknowledges that implementing measures to minimize and mitigate contamination can be a relatively economical way to help ensure the safety of the drinking water.

1.1 WHAT ARE THE BENEFITS OF PREPARING A SOURCE WATER PROTECTION PLAN?

- Fulfilling the requirement for the public water utilities to complete or update their source water protection plan.
- Identifying and prioritizing potential threats to the source of drinking water; and establishing strategies to minimize the threats.
- Planning for emergency response to incidents that compromise the water supply by contamination or depletion, including how the public, state, and local agencies will be informed.
- Planning for future expansion and development, including establishing secondary sources of water.
- Ensuring conditions to provide the safest and highest quality drinking water to customers at the lowest possible cost.
- Providing more opportunities for funding to improve infrastructure, purchase land in the protection area, and other improvements to the intake or source water protection areas.

2.0 BACKGROUND: WV SOURCE WATER ASSESSMENT AND PROTECTION PROGRAM

Since 1974, the federal Safe Drinking Water Act (SDWA) has set minimum standards on the construction, operation, and quality of water provided by public water systems. In 1986, Congress amended the SDWA. A portion of those amendments were designed to protect the source water contribution areas around ground water supply wells. This program eventually became known as the Wellhead Protection Program (WHPP). The purpose of the WHPP is to prevent pollution of the source water supplying the wells.

The Safe Drinking Water Act Amendments of 1996 expanded the concept of wellhead protection to include surface water sources under the umbrella term of Source Water Protection. The amendments encourage states to establish SWAP programs to protect all public drinking water supplies. As part of this initiative states must explain how protection areas for each public water system will be delineated, how potential contaminant sources will be inventoried, and how susceptibility ratings will be established.

In 1999, the WVBPH published the West Virginia Source Water Assessment and Protection Program, which was endorsed by the United States Environmental Protection Agency. Over the next few years, WVBPH staff completed an assessment (i.e., delineation, inventory and susceptibility analysis) for all of West Virginia's public water systems. Each public water system was sent a copy of its assessment report. Information regarding assessment reports for Kanawha Falls PSD can be found in **Table 1**.

3.0 STATE REGULATORY REQUIREMENTS

On June 6, 2014, §16 1 2 and §16 1 9a of the Code of West Virginia, 1931, was reenacted and amended by adding three new sections, designated §16 1 9c, §16 1 9d and §16-1-9e. The changes to the code outlines specific requirements for public water utilities that draw water from a surface water source or a surface water influenced groundwater source.

Under the amended and new codes each existing public water utility using surface water or ground water influenced by surface water as a source must have completed or updated a source water protection plan by July 1, 2016, and must continue to update their plan every three years. Existing source water protection plans have been developed for many public water utilities in the past. If available, these plans were reviewed and considered in the development of this updated plan. Any new water system established after July 1, 2016 must submit a source water protection plan before they start to operate. A new plan is also required when there is a significant change in the potential sources of significant contamination (PSSC) within the zone of critical concern (ZCC).

The code also requires that public water utilities include details regarding PSSCs, protection measures, system capacities, contingency plans, and communication plans. Before a plan can be approved, the local health department and public will be invited to contribute information for consideration. In some instances, public water utilities may be asked to conduct independent studies of the source water protection area and specific threats to gain additional information.

4.0 SYSTEM INFORMATION

Kanawha Falls PSD is classified as a state regulated public utility and operates a community public water system. A community public water system is a system that regularly supplies drinking water from its own sources to at least 15 service connections used by year round residents of the area or regularly serves 25 or more people throughout the entire year. For purposes of this source water protection plan, community public water systems are also referred to as public water utilities. Information on the population served by this utility is presented in **Table 1** below.

Table 1. Population Served by Kanawha Falls PSD

| | | | |
|---|--|---|---|
| Administrative office location: | | Rt. 39, Gauley Bridge, WV 25085 | |
| Is the system a public utility, according to the Public Service Commission rule? | | Yes | |
| Date of Most Recent Source Water Assessment Report: | | June 2004 | |
| Date of Most Recent Source Water Protection Plan: | | September 2010 | |
| Population served directly: | | According to the 2015 PSC Annual Report, Kanawha Falls PSD directly serves around 980 customers, or 2,450 people. | |
| Bulk Water Purchaser Systems: | System Name | PWSID Number | Population |
| | Gauley River PSD (Also purchases some water from the City of Summersville) | WV3301042 | 800 customers or around 2,000 people are served by Kanawha falls. |
| Total Population Served by the Utility: | | The utility serves a total population of around 4,450 people. | |
| Does the utility have multiple source water protection areas (SWPAs)? | | No | |
| How many SWPAs does the utility have? | | 1 | |

5.0 WATER TREATMENT AND STORAGE

As required, Kanawha Falls PSD has assessed their system (e.g., treatment capacity, storage capacity, unaccounted for water, contingency plans) to evaluate their ability to provide drinking water and protect public health. **Table 2** contains information on the water treatment methods and capacity of the utility. Information about the surface sources from which Kanawha Falls PSD draws water can be found in **Table 3**. If the utility draws water from any groundwater sources to blend with the surface water the information about these ground water sources can be found in **Table 4**.

Table 2. Kanawha Falls PSD Water Treatment Information

| | |
|--|---|
| Water Treatment Processes (List All Processes in Order) | Water treatment processes include coagulation, sedimentation, filtration, disinfection, and fluoridation. |
| Current Treatment Capacity (gal/day) | The current treatment capacity of the treatment plant is approximately 1,440,000 gallons/day. |
| Current Average Production (gal/day) | Current average production is around 736,000 gallons/day. |
| Maximum Quantity Treated and Produced (gal) | The maximum quantity that the plant produced in a single day in the last year was around 1,000,000 gallons. |
| Minimum Quantity Treated and Produced (gal) | The minimum quantity produced in a single day in the last year was around 380,000 gallons. |
| Average Hours of Operation | The water treatment plant is staffed and operated an average of 12 hours/day. |
| Maximum Hours of Operation in One Day | The maximum number of hours of operation in a single day in the last year was 24 hours. |
| Minimum Hours of Operation in One Day | The minimum number of hours of operation in a single day in the last year was 7 hours. |
| Number of Storage Tanks Maintained | The water system maintains 6 treated water storage tanks and 3 booster pump stations. |
| Total Gallons of Treated Water Storage (gal) | The total treated water storage capacity of the water system is around 1,235,000 gallons. |
| Total Gallons of Raw Water Storage (gal) | The water system does not have any raw water storage. |

Table 3. Kanawha Falls PSD Surface Water Sources

| Intake Name | SDWIS # | Local Name | Describe Intake | Name of Water Source | Date Constructed / Modified | Frequency of Use (Primary/ Backup/ Emergency) | Activity Status (Active/ Inactive) |
|----------------------|---------|----------------|---|----------------------|-----------------------------|---|------------------------------------|
| Kanawha River Intake | - | Kanawha Intake | The intake is a screened straight pipe that extends approximately 50' into the river. | Kanawha River | 1980 | Primary | Active |

Table 4. Kanawha Falls PSD Groundwater Sources

| Does the utility blend with groundwater? | | | | | No | | | | |
|--|---------|------------|----------------------------|--------------------------------------|------------------|--------------------|----------------|---|------------------------------------|
| Well/Spring Name | SDWIS # | Local Name | Date Constructed/ Modified | Completion Report Available (Yes/No) | Well Depth (ft.) | Casing Depth (ft.) | Grout (Yes/No) | Frequency of Use (Primary/ Backup/ Emergency) | Activity Status (Active/ Inactive) |
| N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

6.0 DELINEATIONS

For surface water systems, delineation is the process used to identify and map the drainage basin that supplies water to a surface water intake. This area is generally referred to as the source water protection area (SWPA). All surface waters are susceptible to contamination because they are exposed at the surface and lack a protective barrier from contamination. Accidental spills, releases, sudden precipitation events that result in overland runoff, or storm sewer discharges can allow pollutants to readily enter the source water and potentially contaminate the drinking water at the intake. The SWPA for surface water is distinguished as a Watershed Delineation Area (WSDA) for planning purposes; and the Zone of Peripheral Concern (ZPC) and Zone of Critical Concern (ZCC) are defined for regulatory purposes.

The WSDA includes the entire watershed area upstream of the intake to the boundary of the State of West Virginia border or a topographic boundary. The ZCC for a public surface water supply is a corridor along streams within the watershed that warrants more detailed scrutiny due to its proximity to the surface water intake and the intake's susceptibility to potential contaminants within that corridor. The ZCC is determined using a mathematical model that accounts for stream flows, gradient and area topography. The length of the ZCC is based on a five-hour time-of-travel of water in the streams to the water intake, plus an additional one-quarter mile below the water intake. Ohio River ZCC delineations are based on ORSANCO guidance and extend 25 miles above the intake. The width of the zone of critical concern is 1,000 feet measured horizontally from each bank of the principal stream and five hundred feet measured horizontally from each bank of the tributaries draining into the principal stream. Ohio River ZCC delineations are based on ORSANCO guidance and extend 25 miles above the intake and one-quarter mile below the intake. The Ohio River ZCC delineations include 1,320 feet (one-quarter mile) measured from the bank of the main stem of the Ohio River and 500 feet on tributary.

The ZPC for a public surface water supply source and for a public surface water influenced groundwater supply source is a corridor along streams within a watershed that warrants scrutiny due to its proximity to the surface water intake and the intake's susceptibility to potential contaminants within that corridor. The ZPC is determined using a mathematical model that accounts for stream flows, gradient and area topography. The length of the zone of peripheral concern is based on an additional five-hour time-of-travel of water in the streams beyond the perimeter of the zone of critical concern, which creates a protection zone of ten hours above the water intake. The width of the zone of peripheral concern is one thousand feet measured horizontally from each bank of the principal stream and five hundred feet measured horizontally from each bank of the tributaries draining into the principal stream.

For groundwater supplies there are two types of SWPA delineations: 1) wellhead delineations and 2) conjunctive delineations, which are developed for supplies identified as groundwater under the direct influence of surface water, or GWUDIs. A wellhead protection area is determined to be the area contributing to the recharge of the groundwater source (well or spring), within a five year time of travel. A conjunctive delineation combines a wellhead protection area for the hydrogeologic recharge and a connected surface area contributing to the wellhead.

Information and maps of the WSDA, ZCC, ZPC and Wellhead Protection Area for this public water supply were provided to the utility and are attached to this report. See **Appendix A. Figures**. Other information about the WSDA is shown in **Table 5**.

Table 5. Watershed Delineation Information

| | |
|--|--|
| Size of WSDA (Indicate units) | The Watershed Delineation Area covers approximately 8,384 square miles. |
| River Watershed Name (8-digit HUC) | Upper Kanawha River Watershed- 05050006 |
| Size of Zone of Critical Concern (Acres) | The ZCC covers approximately 14,325 acres. |
| Size of Zone of Peripheral Concern (Acres) (Include ZCC area) | The zone of peripheral concern covers approximately 69,199 acres, including the ZCC. |
| Method of Delineation for Groundwater Sources | N/A. The system does not have any groundwater sources. |
| Area of Wellhead Protection Area (Acres) | N/A |

7.0 PROTECTION TEAM

One important step in preparing a source water protection plan is to organize a source water protection team who will help develop and implement the plan. The legislative rule requires that water utilities make every effort to inform and engage the public, local government, local emergency planners, the local health department and affected residents at all levels of the development of the protection plan. WVBPH recommends that the water utility invite representatives from these organizations to join the protection team, which will ensure that they are given an opportunity to contribute in all aspects of source water protection plan development. Public water utilities should document their efforts to engage representatives and provide an explanation if any local stakeholder is unable to participate. In addition, other local stakeholders may be invited to participate on the team or contribute information to be considered. These individuals may be emergency response personnel, local decision makers, business and industry representatives, land owners (of land in the protection area), and additional concerned citizens.

The administrative contact for Kanawha Falls PSD is responsible for assembling the protection team and ensuring that members are provided the opportunity to contribute to the development of the plan. The acting members of the Protection Team are listed in **Table 6**.

The role of the protection team members will be to contribute information to the development of the source water protection plan, review draft plans and make recommendations to ensure accuracy and completeness, and when possible contribute to implementation and maintenance of the protection plan. The protection team members are chosen as trusted representatives of the community served by the water utility and may be designated to access confidential data that contains details about the local PSSCs. The input of the protection team will be carefully considered by the water utility when making final decisions relative to the documentation and implementation of the source water protection plan.

Kanawha Falls PSD will be responsible for updating the source water protection plan and rely upon input from the protection team and the public to better inform their decisions. To find out how you can become involved as a participant or contributor, visit the utility website or call the utility phone number, which are provided in **Table 6**.

Table 6. Protection Team Member and Contact Information

| Name | Representing | Title | Phone Number | Email |
|---|--|---|--------------|----------------------------|
| Carl King | Kanawha Falls PSD | Chief Operator | 304-779-2600 | kfpsd_12@yahoo.com |
| Rick Wagner | Kanawha Falls PSD | Utility Manager | 304-632-1633 | kfpsd_12@yahoo.com |
| Roger Wagner | Kanawha Falls PSD | Board Chairman | ██████████ | rwagner@glbsm.com |
| Kim Houghton | Town of Gauley Bridge | Town Recorder | ██████████ | kimhoughton@suddenlink.net |
| Damon Runyon | Gauley Bridge Fire Department | Fire Chief | 304-632-1810 | Damon_47@yahoo.com |
| Chris Farrish | WV DHHR Environmental Engineering Division | WV DHHR District Engineer | 304-575-8524 | chris.b.farrish@wv.gov |
| Date of first protection team meeting | | 4/6/2016 | | |
| Efforts made to inform and engage local stakeholders (public, local government, local emergency planners, local health department, and affected residents) and explain absence of recommended stakeholders: | | <p>The protection team for Kanawha Falls PSD first met on 4/6/2016 at the Kanawha Falls PSD Office in Gauley Bridge, WV. Carl King arranged the meeting and contacted the recommended team members by phone. All recommended team members were present except Chris Farrish, who will be involved in planning efforts in the future. See attached meetings notes in Appendix E. Supporting Documentation for more information.</p> <p>Staff from Kanawha Falls PSD also participated in a public event that was held at Hawks Nest State Park on March 22, 2016. See Table 10. Education and Outreach Implementation Plan for more information. This event fulfilled the public engagement requirement of the source water protection planning process.</p> | | |

8.0 POTENTIAL SOURCES OF SIGNIFICANT CONTAMINATION

Source water protection plans should provide a complete and comprehensive list of the PSSCs contained within the ZCC based upon information obtained from the WVBPH, working in cooperation with the West Virginia Department of Environmental Protection (WVDEP) and the West Virginia Division of Homeland Security and Emergency Management (WVDHSEM). A facility or activity is listed as a PSSC if it has the potential to release a contaminant that could potentially impact a nearby public water supply, and it does not necessarily indicate that any release has occurred.

The list of PSSCs located in the SWPA is organized into two types: 1) SWAP PSSCs, and 2) Regulated Data. SWAP PSSCs are those that have been collected and verified by the WVBPH SWAP program during previous field investigations to form the source water assessment reports and source water protection plans. Regulated PSSCs are derived from federal and state regulated databases, and may include data from WVDEP, US Environmental Protection Agency, WVDHSEM, and out-of-state data sources.

8.1 CONFIDENTIALITY OF PSSCS

A list of the PSSCs contained within the ZCC should be included in the source water protection plan. However, the exact location, characteristics and approximate quantities of contaminants shall only be made known to one or more designees of the public water utility and maintained in a confidential manner. In the event of a chemical spill, release or other related emergency, information pertaining to the contaminant shall be immediately disseminated to any emergency responders reporting to the site. The designees for Kanawha Falls PSD are identified in the communication planning section of the source water protection plan.

PSSC data from some agencies (ex. WVDHSEM, WVDEP, etc.) may be restricted due to the sensitive nature of the data. Locational data will be provided to the public water utility. However, to obtain specific details regarding contaminants, (such as information included in Tier II reports), water utilities should contact the local emergency planning commission (LEPC) or agencies, directly. While the maps and lists of the PSSCs and regulated sites are to be maintained in a confidential manner, these data are provided in **Appendix A. Figures** for internal review and planning uses only.

8.2 LOCAL AND REGIONAL PSSCS

For the purposes of this source water protection plan, local PSSCs are those that are identified by the water utility and local stakeholders and are not already identified in the PSSCs lists distributed by the WVBPH and other agencies. Local stakeholders may identify local PSSCs for two main reasons. The first is that it is possible that threats exist from unregulated sources and land uses that have not already been inventoried and do not appear in regulated databases. For this reason each public water utility should investigate their protection area for local PSSCs. A PSSC inventory should identify all contaminant sources and land uses in the delineated ZCC. The second reason local PSSCs are identified is because public water utilities may consider expanding the PSSC inventory effort outside of the ZCC into the ZPC and WSDA if necessary to properly identify all threats that could impact the drinking water source. As the utility considers threats in the watershed they may consider collaborating with upstream communities to identify and manage regional PSSCs.

When conducting local and regional PSSC inventories, utilities should consider that some sources may be obvious like above ground storage tanks, landfills, livestock confinement areas, highway or railroad right of ways, and sewage treatment facilities. Others are harder to locate like abandoned cesspools, underground tanks, French drains, dry wells, or old dumps and mines.

Kanawha Falls PSD reviewed intake locations and the delineated SWPAs to verify the existence of PSSCs provided by the WVBPH and identify new PSSCs. If possible, locations of regulated sites within the SWPA were confirmed. Information on any new or updated PSSCs identified by Kanawha Falls PSD and not already appearing in datasets from the WVBPH can be found in Table 7.

Table 7. Locally Identified Potential Sources of Significant Contamination

| PSSC Number | Map Code | Site Name | Site Description | Relative Risk Score | Comments |
|------------------------|---------------------|------------------|-------------------------|--------------------------------|-----------------|
| - | - | - | - | - | - |

8.3 PRIORITIZATION OF THREATS AND MANAGEMENT STRATEGIES

Once the utility has identified local concerns, they must develop a management plan that identifies specific activities that will be pursued by the public water utility in cooperation and concert with the WVBPH, local health departments, local emergency responders, LEPC and other agencies and organizations to protect the source water from contamination threats.

Depending on the number identified, it may not be feasible to develop management strategies for all of the PSSCs in the SWPA. The identified PSSCs can be prioritized by potential threat to water quality, proximity to the intake(s), and local concern. The highest priority PSSCs can be addressed first in the initial management plan. Lower ranked PSSCs can be addressed in the future as time and resources allow. To assess the threat to the source water, water systems should consider confidential information about each PSC. This information may be obtained from state or local emergency planning agencies, Tier II reports, facility owner, facility groundwater protection plans, spill prevention response plans, results of field investigations, etc.

In addition to identifying and prioritizing PSSCs within the SWPA, local source water concerns may also focus on critical areas. For the purposes of this source water protection plan, a critical area is defined as an area that is identified by local stakeholders and can lie within or outside of the ZCC. Critical areas may contain one or more PSSCs which would require immediate response to address a potential incident that could impact the source water.

A list of priority PSSCs was selected and ranked by the Kanawha Falls PSD Protection Team. This list reflects the concerns of this specific utility and may contain PSSCs not previously identified and not within the ZCC or ZPC. **Table 8** contains a description of why each critical area or PSC is considered a threat and what management strategies the utility is either currently using or could use in the future to address each threat.

9.0 IMPLEMENTATION PLAN FOR MANAGEMENT STRATEGIES

Kanawha Falls PSD reviewed the recommended strategies listed in their previous source water protection plan, to consider if any of them should be adopted and incorporated in this updated plan. **Table 9** provides a brief statement summarizing the status of the recommended strategies. **Table 9** also lists strategies from a previous plan that are being incorporated in this plan update

When considering source management strategies and education and outreach strategies, this utility has considered how and when the strategies will be implemented. The initial step in implementation is to establish responsible parties and timelines to implement the strategies. The water utility, working in conjunction with the Protection Team members, can determine the best process for completing activities within the projected time periods. Additional meetings may be needed during the initial effort to complete activities, after which the Protection Team should consider meeting annually to review and update the Source Water Protection Plan. A system of regular updates should be included in every implementation plan.

Proposed commitments and schedules may change but should be well documented and reported to the local stakeholders. If possible, utilities should include cost estimates for strategies to better plan for implementation and possible funding opportunities. Kanawha Falls PSD has developed an implementation plan for priority concerns listed in **Table 8**. The responsible team member, timeline, and potential cost of each strategy are presented in **Table 9**. Note: Because timelines may change, future plan updates should describe the status of each strategy and explain the lack of progress. The responsible team member, timeline, and potential cost of each strategy was estimated and is presented in **Table 9**.

Table 8. Priority PSSCs or Critical Areas

| PSSC or Critical Area | Priority Number | Reason for Concern |
|--|-----------------|--|
| Highway and Railway Traffic | 1 | The railroad tracks and highway run parallel to the Kanawha River through the ZCC. Utility staff feel that railways are the primary concern for the water system. A Norfolk Southern line runs parallel to the river upstream of the intake. If an accident were to occur on or along the river, it may be difficult to contain spill materials and these could potentially contaminate the surface water. There is currently no way for utility staff to know what kind of materials are being transported and how often. |
| Hydroelectric Facility | 2 | Hawks Nest hydroelectric facility is located upstream of the intake. Occasionally this facility will report spills or releases to the Kanawha Falls water treatment plant, but always in time for the operators to close the intake. These releases have the potential to impact the water system, but staff at this facility have always effectively communicated any concerns. |
| Potential line breaks from public sewer near surface water | 3 | Public sewer lines run upstream of the intake. If a line break occurs, untreated sewage, could contaminate the surface water source, raising concentrations of Total coliform, particularly fecal coliform. |

Table 9. Priority PSSC Management Strategies

| PSSC or Critical Area | Management Activity | Responsible Protection Team Member | Status/Schedule | Comments | Estimated Cost |
|-----------------------|---|------------------------------------|-----------------|----------|----------------|
| Previous Plan Status | There were 4 management strategies recommended in the existing plan. 2 of these strategies have either been implemented or the priorities they address are no longer a concern for the water system. 2 of these address priorities that are ongoing or continue to be a concern. These are incorporated in this plan update and listed below. | - | - | - | - |

| | | | | | |
|--|--|------------------------------|------------------------------------|---|--|
| Highway and Railway Traffic | Utility personnel will contact Norfolk Southern to learn more about the schedules and cargo of the regular shipments that run through the ZCC. They will continue to coordinate with emergency officials from the county, railroad, and industrial site to be better prepared in the event of a spill or accident. | Utility staff | By 2019 SWPP update | - | Cost associated with staff time and participation in training activities |
| Hydroelectric Facility | Utility staff feel that this potential threat is effectively managed and will maintain constant communication with Hawks Nest Hydro. | Utility staff | Ongoing effort and communication | - | Cost associated with staff time. |
| Potential line breaks from public sewer near surface water | Kanawha Falls PSD water treatment plant staff also manage the public sewer system and are in constant contact with the operators of the sewer system. Continue to monitor the PSD's sewer system to prevent or detect leaks immediately. If necessary, utility staff could extend sewer service to unserved areas in the future. | Utility staff | Ongoing efforts | - | Cost associated with staff time during normal operating hours. |
| Source Water Protection Plan | Update this Source Water Protection Plan at least every 3 years as required by the State Code of West Virginia. | Source Water Protection Team | Every 3 years. Next update in 2019 | The Protection Plan should also be updated any time there is a significant change within the protection area or in utility staff. Yearly meetings of the protection team are recommended to ensure all members are up to date and informed about any developments within the protection area. | Minimal costs associated with team members' time |
| Future Development and Other Activities Within the Watershed | Water utility staff will perform a yearly "windshield survey" of the zone of critical concern. They will note changes in land use, water quality, and other developments that may have occurred since the previous year's survey. These changes will be documented and reflected in future source water protection plan updates. | Water utility staff | Yearly, next survey in 2017 | Document the date of the survey and any changes that may have occurred within the ZCC that could impact water quality. | Minimal cost associated with staff time |
| Yearly Source Water Protection Team Meetings | The Protection Team for Kanawha Falls PSD will meet on a yearly basis to discuss any changes that might have occurred within the watershed or to find replacements for members who can no longer participate on the team. | Source Water Protection Team | Yearly, next meeting in 2017 | - | Minimal cost associated with staff time |

| | | | | | |
|--|---|--|---|---|---|
| Regular Coordination with Emergency Managers | Kanawha Falls PSD staff have worked in the past with Fayette County Office of Emergency Services to respond to emergencies effectively and maintain water service to customers. Utility staff will continue to communicate with these emergency services groups on a regular basis, especially when there is not an ongoing emergency. They will meet yearly as part of the Source Water Protection Team. | Water utility staff and emergency response personnel | Yearly, during regular Protection Team Meetings | - | Minimal cost associated with staff time |
|--|---|--|---|---|---|

10.0 EDUCATION AND OUTREACH STRATEGIES

The goal of education and outreach is to raise awareness of the need to protect drinking water supplies and build support for implementation strategies. Education and outreach activities will also ensure that affected citizens and other local stakeholders are kept informed and provided an opportunity to contribute to the development of the source water protection plan. Kanawha Falls PSD has created an Education and Outreach plan that describes activities it has either already implemented or could implement in the future to keep the local community involved in protecting their source of drinking water. This information can be found in **Table 10**.

Table 10. Education and Outreach Implementation Plan

| Education and Outreach Strategy | Description of Activity | Responsible Protection Team Member | Status/Schedule | Comments | Estimated Cost |
|-----------------------------------|--|------------------------------------|-----------------|--|--|
| Public Meeting | <p>Utility staff participated in a public event hosted by Fayette County and the WV Rivers Coalition. The event took place at Hawks Nest State Park on March 22, 2016. Customers from several utilities attended the event, including Kanawha Falls PSD. Attendees received information about source water protection and the requirements for public water systems. Informational booths were set up for each utility to allow the customers the opportunity to speak with utility staff and review the draft source water protection plans.</p> <p>In addition, utility staff posted a flyer around town and in the PSD office informing customers of their ability to review and comment on the plan.</p> | Utility Staff | March 22, 2016 | <p>Utility staff from Kanawha Falls PSD attended the public event and made themselves available to answer any questions their customers might have. They advertised the meeting for several weeks by posting flyers around Gauley Bridge and by announcing the event at a city council meeting. In all, approximately 30-40 people attended the meeting.</p> <p>Tetra Tech staff developed an informational poster for the public event that is attached in Appendix E. Supporting Documentation.</p> | Minimal cost related to operator time. |
| Consumer Confidence Report | <p>The utility publishes a Consumer Confidence Report (CCR) annually, as required by the Safe Drinking Water Act, which is sent to all water customers. Information concerning the Source Water Assessment is included in the CCR. Include also a reference to this source water protection plan and how customers can access a copy.</p> | Utility Staff | Yearly | This would be in addition to required Source Water Assessment information, including source of water and susceptibility to contamination. | CCR required by SDWA, included in annual budget. |
| Brochures, pamphlets, and letters | <p>Send a brochure providing educational information to residences and businesses. These will alert the recipients of the need for source water protection and conservation. See Appendix E for example brochure that can be customized. Funding for the brochures may be available through the Wellhead and Source Water Protection Grant Program.</p> | Utility Staff | Yearly | <p>The Source Water Collaborative has released an educational brochure building tool to assist with creating custom brochures targeting local decision makers. This tool is available at: http://www.yourwateryourdecision.org and may assist in community planning and development. There is a sample brochure attached in Appendix E that could be used to provide information about source water to customers.</p> | Cost in brochure printing and mailing |

| | | | | | |
|------------------|--|---------------|--|---|--|
| School Curricula | <p>Work with the school system to incorporate source water activities into the school curricula.</p> <p>Visit school or invite students for a plant tour to tie in with school curricula. Ask the school to include messages in school newsletter to raise awareness about source water protection and conservation.</p> | Utility Staff | Yearly, as requested by local schools. | Operator could initiate effort, locate the appropriate individuals in school and/or on local school board. Can provide websites with free education materials to promote source water protection and conservation. Also operator may visit school or invite students for a plant tour to tie in with classroom materials. | Cost associated with staff time to coordinate, visit classroom and provide tour. |
| Plant Tours | Continue to provide tours of the water plant to interested organizations such as watershed groups, schools, colleges and civic organizations. Tours are offered upon request and typically are conducted at least once a year for the college engineering students. | Operator | Regularly | Local Emergency Responders are provided with plant information including the layout and chemicals stored. | Minimal cost associated with operator's time. |

11.0 CONTINGENCY PLAN

The goal of contingency planning is to identify and document how the utility will prepare for and respond to any drinking water shortages or emergencies that may occur due to short and long term water interruption, or incidents of spill or contamination. During contingency planning, utilities should examine their capacity to protect their intake, treatment, and distribution system from contamination. They should also review their ability to use alternative sources and minimize water loss, as well as their ability to operate during power outages. In addition, utilities should report the feasibility of establishing an early warning monitoring system and meeting future water demands.

Isolating or diverting any possible contaminant from the intake for a public water system is an important strategy in the event of an emergency. One commonly used method of diverting contaminants from an intake is establishing booms around the intake. This can be effective, but only for contaminants that float on the surface of the water. Alternatively, utilities can choose to pump floating contaminants from the water or chemically neutralize the contaminant before it enters the treatment facility.

Public utilities using surface sources should be able to close the intake by one means or another. However, depending upon the system, methods for doing so could vary greatly and include closing valves, lowering hatches or gates, raising the intake piping out of the water, or shutting down pumps. Systems should have plans in place in advance as to the best method to protect the intake and treatment facility. Utilities may benefit from turning off pumps and, if possible, closing the intake opening to prevent contaminants from entering the piping leading to the pumps. Utilities should also have a plan in place to sample raw water to identify the movement of a contaminant plume and allow for maximum pumping time before shutting down an intake (See Early Warning Monitoring System). The amount of time that an intake can remain closed depends on the water infrastructure and should be determined by the utility before an emergency occurs. The longer an intake can remain closed in such a case, the better.

Raw and treated water storage capacity also becomes extremely important in the event of such an emergency. Storage capacity can directly determine how effectively a water system can respond to a contamination event and how long an intake can remain closed. Information regarding the water shortage response capability of Kanawha Falls PSD is provided in **Table 11**.

11.1 RESPONSE NETWORKS AND COMMUNICATION

Statewide initiatives for emergency response, including source water related incidents, are being developed. These include the West Virginia Water/Wastewater Agency Response Network (WV WARN, see <http://www.wvwarn.org/>) and the Rural Water Association Emergency Response Team (see <http://www.wvrwa.org/>). Kanawha Falls PSD has analyzed its ability to effectively respond to emergencies and this information is also provided in **Table 11**.

Table 11. Kanawha Falls PSD Water Shortage Response Capability

| | |
|---|---|
| Can the utility isolate or divert contamination from the intake or groundwater supply? | Yes |
| Describe the utility's capability to isolate or divert potential contaminants: | The utility has access to booms they can use to isolate the raw water intake from surface contaminants. WVA Manufacturing, which is located just downstream from the treatment plant, also has booms available. They can also close the intake to isolate it from potential contaminants. |
| Can the utility switch to an alternative water source or intake that can supply full capacity at any time? | No |

| | |
|--|---|
| Describe in detail the utility's capability to switch to an alternative source: | The utility has no means of switching to an alternative source of raw water. |
| Can the utility close the water intake to prevent contamination from entering the water supply? | Yes |
| How long can the intake stay closed? | If the tanks were full when the intake went closed, the water system could operate for 1.7 days. This is partially dependent on the ability of Gauley River PSD, who is supplied by Kanawha Falls, to conserve their water. |
| Describe the process to close the intake: | The operator can manually close a valve to shut off the intake and prevent contaminated raw water from entering the plant. |
| Describe the treated water storage capacity of the water system: | <p>Kanawha Falls PSD has 6 treated water storage tanks and 2 booster pump stations (BPS).</p> <p>Boomer Tank- 200,000 gallons</p> <p>Falls View Tank #1- 300,000 gal.</p> <p>Falls View Tank #2- 300,000 gal.</p> <p>Gauley Bridge High Tank- 107,000 gal.</p> <p>Gauley Bridge Low Tank- 223,000 gal.</p> <p>Charlton Heights Tank- 105,000 gal.</p> <p>Total= 1,235,000 gal. treated water storage</p> <p>The utility does not have any raw water storage.</p> |
| Is the utility a member of WVRWA Emergency Response Team? | The utility is a member of West Virginia Rural Water Association (WVRWA) but not the WVRWA Emergency Response Team. |
| Is the utility a member of WV-WARN? | No |
| List any other mutual aid agreements to provide or receive assistance in the event of an emergency: | The utility has an informal mutual aid agreement with West Virginia American Water in Montgomery, who provided them with water tankers during the 2015 train derailment. |

11.2 OPERATION DURING LOSS OF POWER

Kanawha Falls PSD analyzed its ability to operate effectively during a loss of power. This involved ensuring a means to supply water through treatment, storage, and distribution without creating a public health emergency. Information regarding the utility's capacity for operation during power outages is summarized in **Table 12**.

Table 12. Generator Capacity

| | |
|---|---|
| What is the type and capacity of the generator needed to operate during a loss of power? | The Kanawha Falls water treatment plant requires a 250kW generator, and the two booster stations each require a 50 kW generator to operate during a power outage. They currently do not own any generators, and plan on renting them as needed. |
|---|---|

| | | | |
|--|---|---|------------------------------------|
| Can the utility connect to generator at intake/wellhead? If yes, select a scenario that best describes system. | No. The raw water intake is located directly adjacent to the treatment plant and the pumps are powered by the plant, so a generator is not necessary. | | |
| Can the utility connect to generator at treatment facility? If yes, select a scenario that best describes system. | Yes. The treatment plant is fully wired to be connected to a generator that will be rented or borrowed during a power outage. | | |
| Can the utility connect to a generator in distribution system? If yes, select a scenario that best describes system. | Yes. Both booster pump stations are fully wired for a generator that will be rented or borrowed during a power outage. | | |
| Does the utility have adequate fuel on hand for the generator? | No. Kanawha Falls PSD does not have any on-site fuel storage. | | |
| What is your on-hand fuel storage and how long will it last operating at full capacity? | Gallons | | Hours |
| | None | | N/A |
| Provide a list of suppliers that could provide generators and fuel in the event of an emergency: | Supplier | | Phone Number |
| | Generator | Mountaineer Generator- Elkins, WV | 304-636-0011 or 724-324-2122 |
| | Generator | Walker Caterpillar- Belle, WV | 304-949-6400 |
| | Fuel | West Virginia Division of Highways- Kanawha Falls, WV | 304-647-7450 |
| | Fuel | Sunoco- Montgomery, WV | 304-442-8900 |
| Does the utility test the generator(s) periodically? | N/A | | |
| Does the utility routinely maintain the generator? | N/A | | |
| If no scenario describing the ability to connect to generator matches the utility's system or if utility does not have ability to connect to a generator, describe plans to respond to power outages: | The utility has had no problem renting generators when they needed them in the past and plans to rent them again in the event of a power outage. | | |

11.3 FUTURE WATER SUPPLY NEEDS

When planning for potential emergencies and developing contingency plans, a utility needs to not only consider their current demands for treated water but also account for likely future needs. This could mean expanding current intake sources or developing new ones in the near future. This can be an expensive and time consuming process, and any water utility should take this into account when determining emergency preparedness. Kanawha Falls PSD has analyzed its ability to meet future water demands at current capacity, and this information is included in **Table 13**.

Table 13. Future Water Supply Needs for Kanawha Falls PSD

| | |
|---|--|
| <p>Is the utility able to meet water demands with the current production capacity over the next 5 years? If so, explain how you plan to do so.</p> | <p>Yes- The utility does not expect any significant changes in demand over the next 5 five years, and the treatment plant is currently operating at an average of 50%-60% of capacity. No water line extensions are planned for the next five years, and there is no expected increase in population. The water system's opinions concerning the demand for the next five years are generally supported by population trends projected based on US Census Bureau 2000 and 2010 data. According to the 2005 Interim State Population Projections (1), WV as a whole will see a population decline between 2010 and 2030. In addition, researchers at the WVU College of Business and Economics specifically project that populations within Fayette County will decrease from population of 46,039 in 2010 to a projected population of 44,611 in 2020 (2). Census data and projections cannot account for increases in daily demand due to water line extensions. If in the future water line extension projects are proposed the daily demands will be reassessed to determine if the source and treatment facilities can support increased demand.</p> |
| <p>If not, describe the circumstances and plans to increase production capacity:</p> | <p>N/A</p> |

(1)US Department of Commerce, United State Census Bureau. 2005 Interim State Population Projections. Table 1. <http://www.census.gov/population/projections/data/state/projectionsagesex.html>. Accessed June 10, 2015.

(2) Christiadi, Ph.D., Deskins, John, Ph.D., Lego, Brian. WVU College of Business and Economics, Bureau of Business and Economic Research. March 2014. WVU Research Corporation. <http://be.wvu.edu/bber/pdfs/BBER-2014-04.pdf> Accessed June 10, 2015.

11.4 WATER LOSS CALCULATION

In any public water system there is a certain percentage of the total treated water that does not reach the customer. Some of this water is used in treatment plant processes such as back washing filters or flushing piping, but there is usually at least a small percentage that goes unaccounted for. To measure and report on this unaccounted for water, a public utility must use the method described in the Public Service Commission's rule, *Rules for the Government of Water Utilities*, 150CSR7, section 5.6. The rule defines unaccounted for water as the volume of water introduced into the distribution system less all metered usage and all known non-metered usage which can be estimated with reasonable accuracy.

To further clarify, metered usages are most often those that are distributed to customers. Non-metered usages that are being estimated include usage by fire departments for fires or training, un-metered bulk sells, flushing to maintain the distribution system, and water used for backwashing filters and cleaning settling basins. By totaling the known metered and non-metered uses the utility calculates unaccounted for water. Note: To complete annual reports submitted to the PSC, utilities typically account for known water main breaks by estimating the amount of water lost. However, for the purposes of the source water protection plan, any water lost due to leaks, even if the system is aware of how much water is lost at a main break, is not considered a use. Water lost through leaks and main breaks cannot be controlled during a water shortages or other emergencies and should be included in the calculation of percentage of water loss for purposes of the source water protection plan. The data in **Table 14** is taken from the most recently submitted Kanawha Falls PSD PSC Annual Report.

Table 14. Water Loss Information

| | | |
|--|---|--|
| Total Water Pumped (gal) | | 204,000,000 |
| Total Water Purchased (gal) | | 0 |
| Total Water Pumped and Purchased (gal) | | 204,000,000 |
| Water Loss Accounted for Except Main Leaks (gal) | Mains, Plants, Filters, Flushing, etc. | 0 |
| | Fire Department | 0 |
| | Back Washing | 0 |
| | Blowing Settling Basins | 0 |
| Total Water Loss Accounted For Except Main Leaks | | 0 |
| Water Sold- Total Gallons (gal) | | 182,500,000 |
| Unaccounted For Lost Water (gal) | | 21,489,000 |
| Water lost from main leaks (gal) | | 11,000,000 |
| Total gallons of Unaccounted for Lost Water and Water Lost from Main Leaks (gal) | | 21,500,000 |
| Total Percent Unaccounted For Water and Water Lost from Main Leaks (gal) | | 10.54% |
| If total percentage of Unaccounted for Water is greater than 15%, please describe any measures that could be taken to correct this problem: | | The utility has been successful in keeping their total water loss under 15% and plans to continue to manage their system as efficiently as possible. |

*This information was taken from the 2013 Public Service Commission Annual Report for Kanawha Falls PSD. The 2013 report was used because the 2015 report did not contain information about water production or loss.

11.5 EARLY WARNING MONITORING SYSTEM

Public water utilities are required to provide an examination of the technical and economic feasibility of implementing an early warning monitoring system. Implementing an early warning monitoring system may be approached in different ways depending upon the water utility's resources and threats to the source water. A utility may install a continuous monitoring system that will provide real time information regarding water quality conditions. This would require utilities to analyze the data to establish what condition is indicative of a contamination event. Continuous monitoring will provide results for a predetermined set of parameters. The more parameters that are being monitored, the more sophisticated the monitoring equipment will need to be. When establishing a continuous monitoring system, the utility should consider the logistics of placing and maintaining the equipment, and receiving output data from the equipment.

Alternately, or in addition, a utility may also pull periodic grab samples on a regular basis, or in case of a reported incident. The grab samples may be analyzed for specific contaminants. A utility should examine their PSSCs to determine what chemical contaminants could pose a threat to the water source. If possible, the utility should plan in advance how those contaminants will be detected. Consideration should be given to where samples will be collected, the preservations and hold times for samples, available laboratories to analyze samples, and costs associated with the sampling event. Regardless of the type of monitoring (continuous or grab), utilities should collect samples for their source throughout the year to better understand the baseline water quality conditions and natural seasonal fluctuations. Establishing a baseline will help determine if changes in the water quality are indicative of a contamination event and inform the needed response.

Every utility should establish a system or process for receiving or detecting chemical threats with sufficient time to respond to protect the treatment facility and public health. All approaches to receiving and responding to an early warning should incorporate communication with facility owners and operators that pose a threat to the water quality, with state and local emergency response agencies, with surrounding water utilities, and with the public. Communication plays an important role in knowing how to interpret data and how to respond.

Kanawha Falls PSD has analyzed its ability to monitor for and detect potential contaminants that could impact its source water. Information regarding this utility's early warning monitoring system capabilities is provided in **Table 15** and in **Appendix B**.

Table 15. Early Warning Monitoring System Capabilities

| | | |
|--|--|--|
| <p>Does your system currently receive spill notifications from a state agency, neighboring water system, local emergency responders, or other facilities? If yes, from whom do you receive notices?</p> | <p>Yes. Kanawha Falls PSD has received notices about possible contamination from Brookfield Energy, who manages the hydro-electric plants upstream.</p> <p>The have also received notices from the West Virginia Division of Homeland Security and Emergency Management</p> | |
| <p>Are you aware of any facilities, land uses, or critical areas within your protection areas where chemical contaminants could be released or spilled?</p> | <p>Yes. The utility's primary concerns are the hydro-electric energy plants that operate immediately upstream from the intake. The plants have had issues in the past but maintain regular communication with the operators at Kanawha Falls about any accidents or spills that may occur.</p> | |
| <p>Are you prepared to detect potential contaminants if notified of a spill?</p> | <p>No</p> | |
| <p>List laboratories (and contact information) on whom you would rely to analyze water samples in case of a reported spill.</p> | <p>Laboratories</p> | |
| | <p>Name</p> | <p>Contact</p> |
| | <p>REIC Laboratory- Beaver, WV</p> | <p>800-999-0105, 304-255-2500, info@reiclabs.com</p> |
| | <p>ALS Environmental- South Charleston, WV</p> | <p>304-356-3168</p> |
| | <p>WV State Laboratory, Environmental Chemistry Section- Charleston, WV</p> <p>304-965-2694</p> | |

| | | | | |
|--|--------------------------|---|--|---|
| Do you have an understanding of baseline or normal conditions for your source water quality that accounts for seasonal fluctuations? | | Yes - The utility tests daily for pH, turbidity, chlorine, fluoride, and alkalinity. They have an understanding of normal baseline conditions for their raw water source. | | |
| Does your utility currently monitor raw water (through continuous monitoring or periodic grab samples) at the surface water intake or from a groundwater source on a regular basis? | | No. See Form B in Appendix A . | | |
| Provide or estimate the capital and O&M costs for your current or proposed early warning system or upgraded system. | Monitoring System | YSI EXO 2 (B-1) | Hach sc1000 (B-2) | Real Tech Full Scanning Monitoring System (B-3) |
| | Capital | Total Capital Cost- \$19,000 | Approximate Capital Cost- \$18,907 | Approximate Capital Cost- \$24,155 |
| | Yearly O & M | Parts and calibration- Approximately \$1,000 Data management and telemetry- \$1,000 | Full service contract with Hach Service Representative- \$2,258 Online Viewer-\$600 | Replacement Lamps- \$1,480 Smart-Sense Monitoring Service- \$499 |
| Do you serve more than 100,000 customers? If so, please describe the methods you use to monitor at the same technical levels utilized by ORSANCO. | | No | | |

12.0 SINGLE SOURCE FEASIBILITY STUDY

If a public water utility's water supply plant is served by a single-source intake to a surface water source of supply or a surface water influenced source of supply, the submitted source water protection plan must also include an examination and analysis of the technical and economic feasibility of alternative sources of water to provide continued safe and reliable public water service in the event that its primary source of supply is detrimentally affected by contamination, release, spill event or other reason. These alternatives may include a secondary intake, two days of additional raw or treated water storage, an interconnection with neighboring systems, or other options identified on a local level. Note: a suitable secondary intake would draw water supplies from a substantially different location or water source.

To accomplish this requirement, utilities should examine all existing or possible alternatives and rank them by their technical, economic, and environmental feasibility. To have a consistent and complete method for ranking alternatives, WVBPH has developed a feasibility study guide. This guide provides several criteria to consider for each category, organized in a Feasibility Study Matrix. By completing the Feasibility Study Matrix, utilities will demonstrate the process used to examine the feasibility of each alternative and document scores that compare the alternatives. The Feasibility Study matrix and summary of the results are presented in an alternatives feasibility study attached as **Appendix D**.

13.0 COMMUNICATION PLAN

Kanawha Falls PSD has also developed a Communication Plan that documents the manner in which the public water utility, working in concert with state and local emergency response agencies, shall notify the local health agencies and the public of the initial spill or contamination event and provide updated information related to any contamination or impairment of the system's drinking water supply. The initial notification to the public will occur in any event no later than thirty minutes after the public water system becomes aware of the spill, release, or potential contamination of the public water system. A copy of the source water protection plan and the Communication Plan has been provided to the local fire department. Kanawha Falls PSD will update the Communication Plan as needed to ensure contact information is up to date.

Procedures should be in place to effectively react to the kinds of catastrophic spills that can reasonably be predicted at the source location or within the SWPA. The chain-of-command, notification procedures and response actions should be known by all water system employees.

The WVBPH has developed a recommended communication plan template that provides a tiered incident communication process to provide a universal system of alert levels to utilities and water system managers. The comprehensive Communication Plan for Kanawha Falls PSD is attached as **Appendix C** for internal review and planning purposes only.

The West Virginia Department of Environmental Protection is capable of providing expertise and assistance related to prevention, containment, and clean-up of chemical spills. The West Virginia Department of Environmental Protection Emergency Response 24-hour Phone is 1-800-642-3074. The West Virginia Department of Environmental Protection also operates an upstream distance estimator that can be used to determine the distance from a spill site to the closest public water supply surface water intake.

14.0 EMERGENCY RESPONSE SHORT FORM


A public water utility must be prepared for any number of emergency scenarios and events that would require immediate response. It is imperative that information about key contacts, emergency services, and downstream water systems be posted and readily available in the event of an emergency. Elements of this source water protection plan, such as the contingency planning and communication plan, may contain similar information to the utility's emergency response plan. However, the emergency response plan is to be kept confidential and is not included in this source water protection plan. An Emergency Short Form is included in **Appendix C** to support the Communicate Plan by providing quick access to important information about emergency response and are to be used for internal review and planning purposes only.

15.0 CONCLUSION

This report represents a detailed explanation of the required elements of Kanawha Falls PSD's Source Water Protection Plan. Any supporting documentation or other materials that the utility considers relevant to their plan can be found in **Appendix E**.

This source water protection plan is intended to help prepare community public water systems all over West Virginia to properly handle any emergencies that might compromise the quality of the system's source water supply. It is imperative that this plan is updated as often as necessary to reflect the changing circumstances within the water system. The protection team should continue to meet regularly and continue to engage the public whenever possible. Communities taking local responsibility for the quality of their source water is the most effective way to prevent contamination and protect a water system against contaminated drinking water. Community cooperation, sufficient preparation, and accurate monitoring are all critical components of this source water protection plan, and a multi-faceted approach is the only way to ensure that a system is as protected as possible against source water degradation.

APPENDIX A. FIGURES




TETRA TECH
803 Quarrier Street, Suite 400
Charleston, WV 25301

**Kanawha Falls PSD
PWSID: WV330103
Source Water Protection Plan**

Figure A-1. Watershed Delineation Area

CREATED BY: CEM

DATE: 03/17/16



Legend

- ▭ Zone of Critical Concern
- ▭ Zone of Peripheral Concern
- ▭ Watershed Delineation Area

0 0.5 1 2 Miles




TETRA TECH
803 Quarrier Street, Suite 400
Charleston, WV 25301

Kanawha Falls PSD
PWSID: WV3301037
Source Water Protection Plan

**Figure A-2. Zone of Critical Concern/
Zone of Peripheral Concern**

CREATED BY: CEM

DATE: 03/17/16




TETRA TECH
803 Quarrier Street, Suite 400
Charleston, WV 25301

Kanawha Falls PSD
PWSID: WV330103
Source Water Protection Plan

Figure A-3. All PSSCs in the Watershed Delineation Area

CREATED BY: CEM

DATE: 03/21/16



Legend

Field Verified PSSCs

Agriculture

Commercial

Industrial

Municipal

Residential

Points of Interest

Zone of Critical Concern


Zone of Peripheral Concern

Watershed Delineation Area

N

00.512

Miles




TETRA TECH
803 Quarrier Street, Suite 400
Charleston, WV 25301

Kanawha Falls PSD
PWSID: WV3301037
Source Water Protection Plan

Figure A-5. Selected Sources: Abandoned Mine Land Areas, Highwalls, and Points, and Oil/Gas Wells

CREATED BY: CEM

DATE: 03/17/16




TETRA TECH
 803 Quarrier Street, Suite 400
 Charleston, WV 25301

Kanawha Falls PSD
PWSID: WV3301037
Source Water Protection Plan

Figure A-6. Selected Sources: Landfill Closure Assistance Program Sites, Leaking Underground Storage Tanks, NPDES Permits, and Volunteer Remediation

CREATED BY: CEM

DATE: 03/17/16



*Note: The mining outlet data layer displayed on this figure only includes those records where the inspectable unit type is "OUTLT".

Legend

Bond Forfeiture Sites

Coal Refuse Sites

Mining Permits

of outlets per permit

1 - 5

6 - 12

13 - 22

23 - 34

35 - 57


Zone of Critical Concern

Zone of Peripheral Concern

Watershed Delineation Area

Miles


0 0.5 1 2



Legend

- ★ USEPA Regulated Sites
- Zone of Critical Concern
- Zone of Peripheral Concern
- Watershed Delineation Area

0 0.5 1 2 Miles



TETRA TECH
803 Quarrier Street, Suite 400
Charleston, WV 25301

**Kanawha Falls PSD
PWSID: WV3301037
Source Water Protection Plan**

Figure A-9. Aboveground Storage Tanks

CREATED BY: RWM

DATE: 4/5/2016

List of Regulated PSSCs**Kanawha Falls PSD – PSSC Summary**

| PSSC Layer | In ZCC | Around ZCC | In ZPC | Around ZPC | In Watershed | Total Records |
|--------------------------------------|--------|------------|--------|------------|--------------|---------------|
| Above Ground Storage Tanks | 54 | 57 | 89 | 221 | 1426 | 1847 |
| AML Points | 14 | 3 | 62 | 121 | 395 | 595 |
| Bond Forfeiture | 0 | 3 | 15 | 41 | 238 | 297 |
| Closed Landfills | 0 | 0 | 0 | 1 | 1 | 2 |
| Field Verified PSSCs | 23 | 4 | 53 | 34 | 940 | 1054 |
| Landfill Monitoring Wells | 0 | 0 | 0 | 4 | 0 | 4 |
| LUST | 2 | 0 | 1 | 4 | 131 | 138 |
| Mining Outlets | 38 | 86 | 146 | 482 | 3141 | 3893 |
| NPDES Permits | 11 | 7 | 108 | 163 | 2424 | 2713 |
| Oil/Gas Wells | 140 | 165 | 334 | 505 | 1797 | 2941 |
| Points of Interest | 0 | 0 | 0 | 0 | 25 | 25 |
| USEPA Regulated Sites | 23 | 6 | 74 | 116 | 2423 | 2642 |
| Virginia Field Verified PSSCs | 0 | 0 | 0 | 0 | 153 | 153 |
| Volunteer Remediation | 0 | 0 | 0 | 2 | 24 | 26 |
| Coal Refuse Sites | | | | | | |
| Total | 305 | 331 | 882 | 1694 | 13118 | 16330 |

Field Verified PSSCs (SWAP_PCS) – Figure A-4

| PSSC Number | Site Name | Site Description | Map Code | Relative Risk | Comments |
|-------------|--|--|----------|---------------|------------------------------|
| 1 | Division of Highways Falls View Substation | Road maintenance depots/deicing operations | M-20 | 3.08 | Former National Guard armory |
| 2 | Car Wash - Closed | Car washes | C-8 | 1.70 | Now closed |
| 3 | Napa Care Center and Cogar's Tire Service | Auto repair shops | C-3 | 2.73 | none |

| PSSC Number | Site Name | Site Description | Map Code | Relative Risk | Comments |
|-------------|---|--|----------|---------------|---|
| 4 | Division of Highways maintenance garage | Road maintenance depots/deicing operations | M-20 | 3.08 | Same as R-12. Still used to store gravel. A raised berm surrounds site to prevent runoff. |
| 5 | PCS #4 | Auto repair shops | C-3 | 2.73 | AUTO REPAIR SHOP - STATE ROAD MAINTENANCE GARAGE IN KANAWHA FALLS |
| 6 | LKM Auto Sales, LLC | Car dealerships | C-7 | 1.20 | No auto mechanic shop presently. Wash cars, runoff into sewer system. |
| 7 | Kanawha Falls Community Water | Permitted Discharge Pipe (outfall) | I-27 | 5.07 | G & L Coal Company |
| 8 | Pennington Funeral Home | Funeral services and crematories | C-15 | 1.68 | |
| 9 | Little General Sunoco Station | Gas Stations | C-18 | 2.88 | |
| 10 | PCS #1 | Camp grounds | C-6 | 1.62 | NEW RIVER CAMPGROUND; NEAR RIVER |
| 11 | Car Washes | Car washes | C-8 | 1.70 | |
| 12 | Gauley Bridge Fire Department | Fire Stations | M-6 | 1.19 | |
| 13 | Go Mart Gas Station | Gas Stations | C-18 | 2.88 | |
| 14 | Gauley Auto Care | Auto repair shops | C-3 | 2.73 | |
| 15 | Three River Auto Car Lot | Car dealerships | C-7 | 1.20 | |
| 16 | Gas Well with brine tank | Wells: oil and gas | I-40 | 2.79 | |
| 17 | Brown/Es Service Station | Gas Stations | C-18 | 2.88 | |
| 18 | AUTO REPAIR (ARS3) | Auto repair shops | C-3 | 2.73 | DEAN TIRES, 2 BAYS |
| 19 | Auxier Welding, Inc. | Welding Shops | C-52 | 1.17 | |
| 20 | Wells: oil and gas | Wells: oil and gas | I-40 | 2.79 | Gas Well |
| 21 | Clonch Industries | Wood preserving/treatment facilities | I-41 | 4.72 | |
| 22 | Dixie Grade School | Schools | M-21 | 1.47 | |
| 23 | D & D Auto and Tire Shop | Auto repair shops | C-3 | 2.73 | |
| 24 | Clonch Industries | Sawmills | I-32 | 3.74 | |

| PSSC Number | Site Name | Site Description | Map Code | Relative Risk | Comments |
|-------------|--|------------------------------------|----------|---------------|---|
| 25 | PCS #17 | Mining: Surface | I-24 | 5.22 | SMIS ON BELLS CREEK ROAD (TERRY EAGLE COAL CO.) |
| 26 | Gas Well with brine tank | Wells: oil and gas | I-40 | 2.79 | |
| 27 | PCS #21 Confined Animal Feeding Operations | Confined Animal Feeding Operations | A-3 | 4.93 | CONFINED ANIMAL FEEDLOT IN BENTREE |
| 28 | B-J Used Auto Sales | Car dealerships | C-7 | 1.20 | |
| 29 | Elswick Lumber Company | Sawmills | I-32 | 3.74 | |
| 30 | Appalachian Power - Belva Substation | Utility Substation Transformers | C-49 | 2.95 | |
| 31 | Wells: oil and gas | Wells: oil and gas | I-40 | 2.79 | Gas Well Across Twenty Mile Creek from point. |
| 32 | Gas Well with brine tank | Wells: oil and gas | I-40 | 2.79 | |
| 33 | PCS #28 Illegal Dump | Illegal Dump | M-10 | 6.38 | DUMP SITE AT JODIE |
| 34 | Rich Creek Cemetery | Cemeteries | C-9 | 1.24 | |
| 35 | Well #3 XTO Energy | Wells: oil and gas | I-40 | 2.79 | |
| 36 | Gas Well with brine tank | Wells: oil and gas | I-40 | 2.79 | |
| 37 | PCS #26 | Mining: Surface | I-24 | 5.22 | POWELLTON COAL CO., LLC |
| 38 | West Virginia American Water New River Regional drinking water plant | Drinking Water Treatment Plants | M-5 | 1.50 | |
| 39 | Drinking Water Treatment Plant | Drinking Water Treatment Plants | M-5 | 1.50 | |
| 40 | Evangel Fellowship SBC | Other | M-32 | 0.00 | Formerly Beckwith School |
| 41 | PCS#3 | Wells: water supply | M-31 | 0.00 | WELLS: WATER SUPPLY AT BECKWITH SCHOOL |
| 42 | MIKES CAR WASH (CW1) | Car washes | C-8 | 1.70 | LOCATED ON MOUNTAIN DR. |
| 43 | River Retreat | Above Ground Storage Tanks | C-1 | 6.75 | |
| 44 | New River Foodland #1 | Heating oil companies | C-22 | 3.20 | |
| 45 | Divide Elementary | Other | C-53 | 0.00 | |
| 46 | Nutall Middle School | Above Ground Storage Tanks | C-1 | 6.75 | |
| 47 | Divide Elementary | Heating oil companies | C-22 | 3.20 | |
| 48 | Divide Elementary | Above Ground Storage Tanks | C-1 | 6.75 | |

| PSSC Number | Site Name | Site Description | Map Code | Relative Risk | Comments |
|-------------|---|------------------------------------|----------|---------------|---|
| 49 | MILL CREEK LUXURY CABINS INC. | Above Ground Storage Tanks | C-1 | 6.75 | |
| 50 | WILDWATER EXPEDITIONS | Camp grounds | C-6 | 1.62 | |
| 51 | FACTORY DISCOUNT STORE | Junk yards, scrap and auto | C-25 | 3.36 | |
| 52 | WILDWATER EXPEDITIONS | Above Ground Storage Tanks | C-1 | 6.75 | |
| 53 | WILDWATER EXPEDITIONS | Golf courses | C-20 | 1.17 | |
| 54 | MILL CREEK LUXURY CABINS INC. | Other | C-53 | 0.00 | |
| 55 | Railroad tracks near river | Railroad Tracks (right of way) | M-17 | 4.88 | |
| 56 | New River Gorge parking lot, commercial parking, rest rooms | Park lands | M-15 | 1.47 | |
| 57 | Discharge pipe not found | Permitted Discharge Pipe (outfall) | I-27 | 5.07 | Not found, not reported in plan or shown on figure. |
| 58 | CANYON RIM GIFT SHOP | Cemeteries | C-9 | 1.24 | |
| 59 | CANYON RIM GIFT SHOP | Other | C-53 | 0.00 | |
| 60 | CANYON RIM GIFT SHOP | Golf courses | C-20 | 1.17 | |
| 61 | Campground Complex | Camp grounds | C-6 | 1.62 | |
| 62 | Fayetteville wastewater treatment plant | Wastewater Treatment Plant | M-29 | 4.03 | |
| 63 | Historic gas station | Historic gas stations | C-23 | 3.00 | |
| 64 | AEP Fayetteville Utility Substation Transformers | Utility Substation Transformers | C-49 | 2.95 | |
| 65 | D and L Packette | Historic gas stations | C-23 | 3.00 | duplicate of 1682 |
| 66 | Sherry's Car wash now closed | Car washes | C-8 | 1.70 | duplicate of 1683 |
| 67 | Huse Memorial Park cemetery | Cemeteries | C-9 | 1.24 | |
| 68 | PCS #5 Photo processing/printing | Photo processing/printing | C-38 | 1.61 | PHOTO PROCESSING/PRINTING WHITEWATER PHOTOGRAPHY |
| 69 | Fayette Recycling Center | Recycling/reduction facilities | M-19 | 2.40 | Old drinking water plant |
| 70 | BP Industries Machine and metalworking shops | Machine and metalworking shops | I-20 | 2.55 | Machine Shop |
| 71 | BERWIND LAND COMPANY | Wells: oil and gas | I-40 | 2.79 | PEAKE OPERATING COMPANY |

| PSSC Number | Site Name | Site Description | Map Code | Relative Risk | Comments |
|-------------|--------------------------------------|---|----------|---------------|----------------------------------|
| 72 | BERWIND LAND COMPANY | Wells: oil and gas | I-40 | 2.79 | PEAKE OPERATING COMPANY |
| 73 | WHITEWATER INN | Wastewater Treatment Plant | M-29 | 4.03 | Sewage Treatment Plant |
| 74 | Industrial Storage Area | Other | I-44 | 0.00 | Industrial Storage |
| 75 | BTB Wrecker Services | Junk yards, scrap and auto | C-25 | 3.36 | Car Wash, Wrecker Shop, Junkyard |
| 76 | Fayette Square | Parking lots/malls | C-35 | 1.53 | Parking Lot/Mall |
| 77 | Exxon | Gas Stations | C-18 | 2.88 | Gas Station |
| 78 | Chevron | Gas Stations | C-18 | 2.88 | Gas Station/Mini Mart |
| 79 | AML Refuse Pile | Mines: abandoned | I-23 | 5.04 | Refuse Pile |
| 80 | Septic Systems | Septic Systems (discharging to stream or surface) | R-5 | 5.70 | Septic Systems |
| 81 | Perfect Image Body Shop | Body shops | C-5 | 2.84 | Auto Body Repair Shop |
| 82 | Johnsons Auto Body | Body shops | C-5 | 2.84 | Auto Body Repair Shop |
| 83 | Well | Wells: water supply | M-31 | 0.00 | Mine source |
| 84 | NATONAL PARK SERVICE THURMOND DEPOT | Other | C-53 | 0.00 | |
| 85 | NATIONAL PARK SERVICE THURMOND DEPOT | Golf courses | C-20 | 1.17 | |
| 86 | NATIONAL PARK SERVICE THURMOND DEPOT | Radioactive waste disposal sites | M-16 | 3.04 | |
| 87 | NATIONAL PARK SERVICE THURMOND DEPOT | Other | C-53 | 0.00 | |
| 88 | New River Gorge Dun Glen | Recreational vehicle/mini storage | C-42 | 0.75 | |
| 89 | New River Gorge Dun Glen | Above Ground Storage Tanks | C-1 | 6.75 | Propane Tank |
| 90 | New River Gorge Dun Glen | Auto repair shops | C-3 | 2.73 | |
| 91 | New River Gorge Dun Glen | Fuel Oil Storage | R-1 | 2.57 | |
| 92 | New River Gorge Dun Glen | Above Ground Storage Tanks | C-1 | 6.75 | Propane Tank |
| 93 | New River Gorge Dun Glen | Septic Systems (leach field)* | R-6 | 2.13 | |
| 94 | NEW RIVER GORGE DUN GLEN | Above Ground Storage Tanks | C-1 | 6.75 | |
| 95 | New River Gorge Dun Glen | Above Ground Storage Tanks | C-1 | 6.75 | Propane Tank |
| 96 | NEW RIVER GORGE DUN GLEN | Above Ground Storage Tanks | C-1 | 6.75 | |

| PSSC Number | Site Name | Site Description | Map Code | Relative Risk | Comments |
|-------------|--------------------------|-------------------------------|----------|---------------|----------|
| 97 | New River Gorge Dun Glen | Septic Systems (leach field)* | R-6 | 2.13 | |
| 98 | New River Gorge Dun Glen | Septic Systems (leach field)* | R-6 | 2.13 | |

Only 98 of 1054 points were prioritized and labeled due to their potential threat level or proximity to the intake. The remaining points should be considered by the water system but were not prioritized in this analysis.

Abandoned Mine Lands – Figure A-5

| PSSC Number | Regulation Type | Pad Number | Pad Name |
|-------------|-----------------|------------|--------------------|
| R-1 | AML_Points | WV004156 | MILL CREEK COMPLEX |

Only 1 of 592 point was prioritized and labeled due to its proximity to the intake. The remaining points lie within the watershed and should be considered by the utility but were not prioritized in this analysis.

Note: PSSCs R-2 through R-48 were relabeled as ASTs.

Bond Forfeiture Sites – Figure A-7

| PSSC Number | Regulation Type | Company | Permit Number | Date Revoked |
|-------------|-----------------|-----------------------------|---------------|--------------|
| R-49 | SPREC | CHICOPEE COAL COMPANY, INC. | O-6021-89 | 1/31/2003 |
| R-50 | SPREC | G & L COAL CO. | S-3035-87 | 5/21/1996 |
| R-51 | SPREC | G & L COAL CO. | U-3036-87 | 5/21/1996 |

Only 3 of 296 points were prioritized and labeled in this analysis. The remaining points in the watershed should be considered important by the water system, but were not prioritized in this analysis. In addition, only one site per unique permit was labeled, so some of these permits may have more than one outlet.

Mining Outlets – Figure A-7

| PSSC Number | Regulation Type | Permit Number | Responsible Party | Status Flag | Permit Count |
|-------------|-----------------|---------------|------------------------|-------------|--------------|
| R-52 | HPU | WV1000951 | G & L COAL CO | C | 14 |
| R-53 | HPU | WV0097144 | KANAWHA ENERGY COMPANY | O | 5 |
| R-54 | HPU | WV0097110 | APPALACHIAN MINING INC | C | 16 |
| R-55 | HPU | WV1001442 | APPALACHIAN MINING INC | C | 6 |

| PSSC Number | Regulation Type | Permit Number | Responsible Party | Status Flag | Permit Count |
|-------------|-----------------|---------------|------------------------|-------------|--------------|
| R-56 | HPU | WV1022504 | KANAWHA ENERGY COMPANY | O | 17 |

Only 5 of 530 points were prioritized and labeled in this analysis. The remaining points in the watershed should be considered important by the water system, but were not prioritized in this analysis. In addition, only one site per unique permit was labeled, so some of these permits may have more than one outlet.

NPDES Permits – Figure A-6

| PSSC Number | Regulation Type | Permit ID | Facility Name | Permit Type |
|-------------|------------------|-----------|-----------------------------------|-------------|
| R-57 | OWRNPDES_Permits | WVG980103 | Falls View Substation | Industrial |
| R-58 | OWRNPDES_Permits | WVG980105 | Glen Ferris Stockpile | Industrial |
| R-59 | OWRNPDES_Permits | WV0116301 | Hawks Nest Hydroelectric Facility | Industrial |
| R-60 | OWRNPDES_Permits | WVG551477 | Downey Ridge Environmental Co | Sewage |
| R-61 | OWRNPDES_Permits | WVG640137 | Fayette Plateau (New River) WTP | Industrial |
| R-62 | OWRNPDES_Permits | WVG611275 | Auxier Welding Inc | Industrial |

Only 6 of 2713 points were prioritized and labeled in this analysis. The remaining points in the watershed should be considered important by the water system, but were not prioritized in this analysis.

USEPA Regulated Sites – Figure A-8

| PSSC Number | Regulation Type | Primary Name | Registry ID | Registry |
|-------------|-----------------|------------------------------|--------------|--------------|
| R-63 | Superfund_RCRA | | 110020977898 | 110021000000 |
| R-64 | Superfund_RCRA | FALLS VIEW SUBSTATION | 110041949498 | 110042000000 |
| R-65 | Superfund_RCRA | MONTGOMERY ARMORY | 110054935326 | 110055000000 |
| R-66 | Superfund_RCRA | FAYETTE CO.-SUBHEADQUARTERS | 110054951904 | 110055000000 |
| R-67 | Superfund_RCRA | DEEPWATER AT KANAWHA FALLS | 110055012141 | 110055000000 |
| R-68 | Superfund_RCRA | GLEN FERRIS STOCKPILE | 110037938943 | 110038000000 |
| R-69 | Superfund_RCRA | G & L COAL COMPANY (S-3035 | 110054953163 | 110055000000 |
| R-70 | Superfund_RCRA | RIVER RIDGE AT KANAWHA FALLS | 110054997152 | 110055000000 |
| R-71 | Superfund_RCRA | JOHN'S GAULEY AUTO CARE | 110007890274 | 110008000000 |
| R-72 | Superfund_RCRA | GAULEY BRIDGE ELEMENTARY | 110021735069 | 110022000000 |

| PSSC Number | Regulation Type | Primary Name | Registry ID | Registry |
|-------------|-----------------|--|--------------|--------------|
| R-73 | Superfund_RCRA | LITTLE GENERAL STORE #3060 | 110033161548 | 110033000000 |
| R-74 | Superfund_RCRA | J C BAKER - GAULEY BRIDGE UST PULL | 110039589022 | 110040000000 |
| R-75 | Superfund_RCRA | GAULEY BRIDGE VFD / FORMER SERVICE STATION / JC BAKER & SON (USTS) | 110041687467 | 110042000000 |
| R-76 | Superfund_RCRA | GAULEY BRIDGE | 110046140948 | 110046000000 |
| R-77 | Superfund_RCRA | HAWKS NEST HYDRO | 110028045960 | 110028000000 |
| R-78 | Superfund_RCRA | HAWKS NEST HYDROELECTRIC FACIL | 110037519726 | 110038000000 |
| R-79 | Superfund_RCRA | CSX TRANSPORTATION BRIDGE REPL | 110046133698 | 110046000000 |
| R-80 | Superfund_RCRA | CARBONDALE TOWER 117 69 KV LIN | 110045520539 | 110046000000 |
| R-81 | Superfund_RCRA | HONEY CREEK BRIDGE, S310-16-23 | 110055011589 | 110055000000 |
| R-82 | Superfund_RCRA | CHIMNEY CORNER - TURKEY CREEK | 110054990907 | 110055000000 |
| R-83 | Superfund_RCRA | FAYETTE CO. REGIONAL WATER PRO | 110054952949 | 110055000000 |
| R-84 | Superfund_RCRA | LAMBS CONCRETE PRODUCTS CORP | 110054962073 | 110055000000 |
| R-85 | Superfund_RCRA | FAYETTE PLATEAU | 110046130441 | 110046000000 |
| R-86 | Superfund_RCRA | HAWKS NEST STATE PARK | 110054957944 | 110055000000 |
| R-87 | Superfund_RCRA | HAWKS NEST STATE PARK | 110054964829 | 110055000000 |
| R-88 | Superfund_RCRA | WV BROADBAND GRANT #2672 FAYET | 110055016227 | 110055000000 |
| R-89 | Superfund_RCRA | AUXIER WELDING INC | 110007881499 | 110008000000 |
| R-90 | Superfund_RCRA | AUXIER WELDING INC | 110031111730 | 110031000000 |
| R-91 | Superfund_RCRA | RELOCATION WV 39+1, U310-39-5. | 110055036973 | 110055000000 |

Only 29 of 219 points were prioritized and labeled in this analysis. The remaining points in the watershed should be considered important by the water system, but were not prioritized in this analysis.

Aboveground Storage Tanks (AST_Chemicals) – Figure A-9

| PSSC Number | Facility Name | Responsible Party | Tank Label | Year | Capacity | Contents |
|-------------|-----------------------------|--------------------------------|--------------|------|----------|----------|
| R-92 | Hutchs Wrecker Service | MAXUM PETROLUEM PRODUCTS, INC. | 010-00000339 | 2008 | | |
| R-93 | Kanawha Energy Company | KANAWHA ENERGY COMPANY | 010-00000617 | 2004 | | |
| R-94 | Brown's Service Station | BROWNS SERVICE STATION | 034-00000315 | 1990 | | |
| R-95 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000048 | 2000 | | |

| PSSC Number | Facility Name | Responsible Party | Tank Label | Year | Capacity | Contents |
|-------------|-----------------------------|------------------------|--------------|------|----------|----------|
| R-96 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000051 | 2005 | | |
| R-97 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000057 | 1964 | | |
| R-98 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000058 | 1968 | | |
| R-99 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000064 | 1999 | | |
| R-100 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000070 | 1974 | | |
| R-101 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000071 | 1996 | | |
| R-102 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000072 | 1996 | | |
| R-103 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000073 | 2005 | | |
| R-104 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000074 | 2005 | | |
| R-105 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000075 | 2009 | | |
| R-106 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000076 | 2009 | | |
| R-107 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000078 | 2007 | | |
| R-108 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000079 | 2006 | | |
| R-109 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000084 | 2010 | | |
| R-110 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000087 | 1999 | | |
| R-111 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000095 | 2000 | | |
| R-112 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000098 | 2001 | | |
| R-113 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000104 | 1996 | | |
| R-114 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000105 | 1996 | | |
| R-115 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000106 | 1968 | | |
| R-116 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000121 | 2002 | | |
| R-117 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000122 | 2005 | | |
| R-118 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000129 | 2006 | | |
| R-119 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000138 | 2005 | | |
| R-120 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000140 | 1985 | | |
| R-121 | KV Oil & Gas FA0558 | HAYDEN HARPER ENERGY | 010-00000150 | 1994 | | |
| R-122 | KV Oil & Gas FA0512 | HAYDEN HARPER ENERGY | 010-00000152 | 1992 | | |
| R-123 | KV Oil & Gas FA0510 | HAYDEN HARPER ENERGY | 010-00000154 | 1991 | | |
| R-124 | KV Oil & Gas FA0563 | HAYDEN HARPER ENERGY | 010-00000155 | 1996 | | |
| R-125 | KV OIL & GAS FA515 | HAYDEN HARPER ENERGY | 010-00000156 | 1992 | | |

| PSSC Number | Facility Name | Responsible Party | Tank Label | Year | Capacity | Contents |
|-------------|---------------------|-----------------------------|--------------|------|----------|----------|
| R-126 | 10490 | CNX GAS COMPANY LLC | 010-00000186 | 1987 | | |
| R-127 | 13046 | CNX GAS COMPANY LLC | 010-00000190 | 1993 | | |
| R-128 | KV Oil & Gas FA0522 | HAYDEN HARPER ENERGY | 010-00000193 | 1994 | | |
| R-129 | KV Oil & Gas FA0505 | HAYDEN HARPER ENERGY | 010-00000196 | 1991 | | |
| R-130 | KV Oil & Gas FA0516 | HAYDEN HARPER ENERGY | 010-00000197 | 1992 | | |
| R-131 | KV Oil & Gas FA0524 | HAYDEN HARPER ENERGY | 010-00000198 | 1992 | | |
| R-132 | KV Oil & Gas FA0521 | HAYDEN HARPER ENERGY | 010-00000199 | 1997 | | |
| R-133 | KV Oil & Gas FA0526 | HAYDEN HARPER ENERGY | 010-00000200 | 1992 | | |
| R-134 | KV Oil & Gas FA0527 | HAYDEN HARPER ENERGY | 010-00000201 | 1992 | | |
| R-135 | KV Oil & Gas FA0528 | HAYDEN HARPER ENERGY | 010-00000202 | 1992 | | |
| R-136 | KV Oil & Gas FA0529 | HAYDEN HARPER ENERGY | 010-00000203 | 1997 | | |
| R-137 | KV Oil & Gas FA0530 | HAYDEN HARPER ENERGY | 010-00000204 | 1992 | | |
| R-138 | KV Oil & Gas FA0533 | HAYDEN HARPER ENERGY | 010-00000205 | 1992 | | |
| R-139 | KV Oil & Gas FA0536 | HAYDEN HARPER ENERGY | 010-00000206 | 1997 | | |
| R-140 | KV Oil & Gas FA0547 | HAYDEN HARPER ENERGY | 010-00000207 | 1992 | | |
| R-141 | KV Oil & Gas FA0555 | HAYDEN HARPER ENERGY | 010-00000208 | 1994 | | |
| R-142 | KV Oil & Gas FA0556 | HAYDEN HARPER ENERGY | 010-00000209 | 1994 | | |
| R-143 | Midvale E0400 10 | HAYDEN HARPER ENERGY | 010-00000211 | 1996 | | |
| R-144 | Midevale E0407 13 | HAYDEN HARPER ENERGY | 010-00000212 | 1996 | | |
| R-145 | KV Oil & Gas FA509 | HAYDEN HARPER ENERGY | 010-00000222 | 1991 | | |
| R-146 | KV Oil & Gas FA0550 | HAYDEN HARPER ENERGY | 010-00000317 | 1994 | | |
| R-147 | Maben Office | EXCO RESOURCES (PA), LLC | 010-00000369 | 2009 | | |
| R-148 | Maben Office | EXCO RESOURCES (PA), LLC | 010-00000370 | 2009 | | |
| R-149 | KV Oil & Gas FA0503 | HAYDEN HARPER ENERGY | 010-00000386 | 1992 | | |
| R-150 | KV Oil & Gas FA0504 | HAYDEN HARPER ENERGY | 010-00000387 | 1991 | | |
| R-151 | Fayette 341X Meter | HAYDEN HARPER ENERGY | 010-00000388 | 2000 | | |
| R-152 | Peabody Coal 7 | CABOT OIL & GAS CORPORATION | 010-00000461 | 1998 | | |
| R-153 | KV Oil & Gas FA0506 | HAYDEN HARPER ENERGY | 010-00000464 | 1992 | | |
| R-154 | Midvale E0401 11 | HAYDEN HARPER ENERGY | 010-00000467 | 1996 | | |
| R-155 | KV OIL & GAS FA559 | HAYDEN HARPER ENERGY | 010-00000502 | 1994 | | |

| PSSC Number | Facility Name | Responsible Party | Tank Label | Year | Capacity | Contents |
|-------------|-----------------------------|--------------------------------|--------------|------|----------|----------|
| R-156 | KV OIL & GAS FA0525 | HAYDEN HARPER ENERGY | 010-00000507 | 1994 | | |
| R-157 | Rhyan 2 | CABOT OIL & GAS CORPORATION | 034-00000300 | 1974 | | |
| R-158 | Hawks Nest Hydro LLC | GARLETTS, RANDY | 010-00000563 | 2013 | | |
| R-159 | Appalachian Handwoods | MAXUM PETROLUEM PRODUCTS, INC. | 010-00000407 | 2008 | | |
| R-160 | ENERVEST OPERATING, LLC | ENERVEST OPERATING L. L. C. | 010-00000005 | 1985 | | |
| R-161 | ENERVEST OPERATING, LLC | ENERVEST OPERATING L. L. C. | 010-00000007 | 1985 | | |
| R-162 | ENERVEST OPERATING, LLC | ENERVEST OPERATING L. L. C. | 010-00000014 | 1985 | | |
| R-163 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000049 | 2000 | | |
| R-164 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000052 | 2005 | | |
| R-165 | Madison Production District | EQT PRODUCTION COMPANY | 010-00000110 | 1974 | | |
| R-166 | 10494 | CNX GAS COMPANY LLC | 010-00000175 | 1987 | | |
| R-167 | Camden #2 & #4 | BUCKEYE OIL PRODUCING CO | 010-00000184 | 2005 | | |
| R-168 | 10489 | CNX GAS COMPANY LLC | 010-00000185 | 1987 | | |
| R-169 | 10479 | CNX GAS COMPANY LLC | 010-00000187 | 1987 | | |
| R-170 | 10491 | CNX GAS COMPANY LLC | 010-00000188 | 1987 | | |
| R-171 | 12997 | CNX GAS COMPANY LLC | 010-00000189 | 1991 | | |
| R-172 | Semet Solvay #13 1674 | HAYDEN HARPER ENERGY | 010-00000213 | 2004 | | |
| R-173 | Semet Solvay #13 1674 | HAYDEN HARPER ENERGY | 010-00000214 | 2004 | | |
| R-174 | Semet Solvay #14 1675 | HAYDEN HARPER ENERGY | 010-00000215 | 2004 | | |
| R-175 | Semet Solvay #15 1676 | HAYDEN HARPER ENERGY | 010-00000216 | 2004 | | |
| R-176 | Semet Solvay #16 1677 | HAYDEN HARPER ENERGY | 010-00000217 | 2004 | | |
| R-177 | Semet Solvay #17 1678 | HAYDEN HARPER ENERGY | 010-00000218 | 2004 | | |
| R-178 | Semet Solvay #18 1679 | HAYDEN HARPER ENERGY | 010-00000219 | 2004 | | |
| R-179 | Calhoun County, WV Tanks | CNX GAS COMPANY LLC | 010-00000224 | 1991 | | |
| R-180 | KV Oil & Gas FA0506 | HAYDEN HARPER ENERGY | 010-00000463 | 1992 | | |
| R-181 | Fayette Co E0341T | HAYDEN HARPER ENERGY | 010-00000466 | 1988 | | |
| R-182 | MORRIS D 1657 | HAYDEN HARPER ENERGY | 010-00000501 | 1985 | | |

| PSSC Number | Facility Name | Responsible Party | Tank Label | Year | Capacity | Contents |
|-------------|--------------------------------------|--------------------------------|--------------|------|----------|----------|
| R-183 | SEMET SOLVAY #11 1672 | HAYDEN HARPER ENERGY | 010-00000573 | 2004 | | |
| R-184 | SEMET SOLVAY COMPRESSOR | HAYDEN HARPER ENERGY | 010-00000575 | 2003 | | |
| R-185 | Hawks Nest Hydro LLC | GARLETTS, RANDY | 010-00000562 | 2011 | | |
| R-186 | KV OIL & GAS FA0513 | HAYDEN HARPER ENERGY | 010-00000151 | 1992 | | |
| R-187 | KV OIL & GAS FA0511 | HAYDEN HARPER ENERGY | 010-00000504 | 1992 | | |
| R-188 | Hawks Nest Hydro LLC | GARLETTS, RANDY | 010-00000566 | 1998 | | |
| R-189 | Fayette County Board of Education | MAXUM PETROLUEM PRODUCTS, INC. | 010-00000353 | 2010 | | |
| R-190 | WVAW New River Water Treatment Plant | WV AMERICAN WATER CO | 010-00000551 | 1999 | | |
| R-191 | WVAW New River Water Treatment Plant | WV AMERICAN WATER CO | 010-00000554 | 1999 | | |
| R-192 | Hawks Nest Hydro LLC | GARLETTS, RANDY | 010-00000564 | 1930 | | |
| R-193 | Hawks Nest Hydro LLC | GARLETTS, RANDY | 010-00000565 | 1930 | | |
| R-194 | Fields Creek Storage Area | LOADOUT, LLC | 010-00000594 | 1992 | | |
| R-195 | Fayette County/Falls View Substation | WVDOH-EQUIPMENT DIVISION | 010-00000191 | 2005 | | |
| R-196 | Fayette County/Falls View Substation | WVDOH-EQUIPMENT DIVISION | 010-00000191 | 2005 | | |
| R-197 | WVAW New River Water Treatment Plant | WV AMERICAN WATER CO | 010-00000552 | 1999 | | |
| R-198 | WVAW New River Water Treatment Plant | WV AMERICAN WATER CO | 010-00000553 | 1999 | | |

Only 107 of 2670 sites were prioritized and labeled due to their potential threat or proximity to the intake. The remaining points in the watershed should be considered to be important by the water system but were not prioritized in this analysis. Additionally, Regulated Points R-2 – R-48 were omitted from the PSSC list.

APPENDIX B. EARLY WARNING MONITORING SYSTEM FORMS

Form B - Proposed Early Warning Monitoring Systems

Kanawha Falls PSD

Primary Surface Water Source:

There are many possible solutions for designing and installing an early warning monitoring system. Over time, this technology changes and improves and it is difficult to determine the type of equipment that will be useful and effective in the long term. This plan is a proposed system that would work for Kanawha Falls PSD using current technology and the current plant and intake configuration.

The primary raw water source for Kanawha Falls PSD is the Kanawha River and the intake is located directly in front of the water treatment plant on the riverbank, about 150' away.

| B-1. YSI EXO 2 Monitoring System Proposal |
|---|
| <p>Describe the type of early warning detection equipment that could be installed, including the design.</p> <p>The YSI EXO 2 Multiport Sonde can accommodate 6 different sensors and has an automatic wiper mechanism to remove biofouling from the sensor tips, which reduces maintenance time. The sonde is built to be resilient and low maintenance, and is capable of providing online water quality monitoring that can be transmitted real time to a designated PC or website that can be accessed by any designated user.</p> <p>The sonde can hold up to 6 sensors, but this plan recommends 4 of the more basic sensors that would be sufficient to detect any sudden shifts in water quality in any West Virginia stream or river. These sensors would include: conductivity/temperature, optical dissolved oxygen, pH, and fluorescent dissolved organic matter (fDOM). The fDOM sensor could potentially detect petroleum products in the water but is not entirely reliable for this purpose. At this time, YSI does not make a sensor for petroleum products for the EXO 2 but likely will in the future, at which time it is recommended that the utility purchase it. Other sensors could be purchased in the future as well if deemed necessary by the utility.</p> |
| <p>Where would the equipment be located?</p> <p>The sonde would be attached to the intake pipe itself, which extends only a few feet into the Kanawha River. This would provide a stable foundation for the equipment and also ensure that the device is able to sample the water that is actually entering the intake pipe and not missing potential contaminants because it is located on the wrong side of the stream or too far from the intake. The suggested method of mounting the sonde involves drilling holes in a PVC pipe, capping the end, inserting the sonde and attaching to the intake pipe structure using brackets or chains. This will protect the sensor from debris and hide it from view somewhat.</p> <p>The sonde would be hardwired to the YSI Storm 3 data analysis/telemetry system. Since the Kanawha Falls PSD water treatment plant is so close to the intake, the Storm 3 could be located in the plant itself. If this was not possible and it needed to be located on the bank closer to the intake, the unit is contained in a waterproof case and comes with a solar photovoltaic panel capable of powering both the data analysis unit and the sonde, so long as the sonde is hardwired to the Storm 3. The device can be battery powered as well if this is not an option.</p> |

What would the maintenance plan for the monitoring equipment entail?

The maintenance plan for the system would involve replacing the dissolved oxygen sensor cap, replacing the pH electrode cap, and purchasing pH, turbidity, and conductivity calibration solution on a yearly basis. The sonde itself is designed to last from 5-10 years and should be inspected and calibrated once a month.

In addition, there is a recurring yearly fee associated with the real-time data/telemetry package for managing the website and data analysis.

Describe the proposed sampling plan at the monitoring site.

The sonde can be programmed to take regular measurements at any intervals defined by the operator or user. These measurements can also be taken in bursts, averaged over a period of time, or modified automatically as water quality levels change. Data is stored in the Storm 3 and transmitted to the plant computer as it is recorded. This information can be transmitted wirelessly via a cellular modem. The cellular transmitter is powerful enough to work even in areas with poor cell reception.

Describe the proposed procedures for data management and analysis.

The Storm 3 package includes data management software that can generate data reports and presentations and allow the user to modify and adjust sampling schedules remotely from the plant.

The sonde can be programmed to alert the user when any of the water quality parameters exceeds a user-defined level. This will allow the operator to program the system to notify them when their previously observed baseline conditions are exceeded in time for them to shut down the pumps and close off the intake. The operator can receive alerts via text message and email at the treatment plant computer or any designated cell phone.

B-2. Hach sc1000 Monitoring System Proposal

Describe the type of early warning detection equipment that could be installed, including the design.

The Hach sc1000 online monitoring system includes a controller, back panel, display module, and trough. Raw water is pumped into the trough from the source where it can be sampled in real time. The probe module can accommodate up to 6 sensors, which means it can monitor up to 6 parameters at once. This plan suggests the following sensors: conductivity, pH, turbidity, and dissolved oxygen. Hach can also supply a sensor to detect oil in water, which would cost an additional \$18,414.00 and would possibly be a good investment for any water system if sufficient funds were available. This sensor is not included in the quoted capital cost. There are several other probes for other parameters that are available from Hach, and these could be purchased as deemed necessary by the utility.

Where would the equipment be located?

The sc1000 Controller, back panel, and trough could be located in the plant itself. A small diameter line would run out from the plant the length of the intake pipe to pull raw water back to the controller where it would flow into the trough for sampling. The closer this sampling line can be to the actual intake, the more accurately it will reflect the raw water that is actually entering the plant. This option would require the utility to purchase a

line or hose long enough to reach the intake pipe and a small pump. The line and pump could be fairly low-tech and inexpensive, as the sc1000 only requires a minimum of 900 mL/min. of flow.

The controller will be equipped with the MODBUS advanced communications/networking unit, which can transmit readings in real time directly to the SCADA system in the treatment plant to alert the operators in any change in baseline water quality. The sc1000 can either be hardwired to the computer at the treatment plant or it can use a cellular modem to transmit the data if there is sufficient cellular signal.

What would the maintenance plan for the monitoring equipment entail?

The maintenance plan for the system would entail a yearly maintenance contract with the manufacturer. A Hach Service Representative would regularly service the monitoring equipment. This service would take care of all parts, labor, and preventative maintenance and would include 2-3 scheduled maintenance visits per year.

Describe the proposed sampling plan at the monitoring site.

The sc1000 monitors the quality of water flowing through the trough in real time, and can transmit this data back to the plant as it is collected. The actual timing of the sampling plan could be determined by the utility.

Describe the proposed procedures for data management and analysis.

It is recommended that the utility purchase the Hach Universal Data Gateway software, which would help to process and analyze the incoming information into easily interpreted reports. The price of this software is included in the rough capital cost.

B-3. Real Tech Full Scanning UV-VIS Monitoring System

Describe the type of early warning detection equipment that could be installed, including the design.

The Real Tech Full Scanning UV-VIS monitoring system provides full ultraviolet/visible scanning for organics and other specific parameters that may indicate a contamination event. The included PC Controller is pre-loaded with the software needed to store and process this information to establish a “normal” or “baseline” set of conditions for the raw water source. In addition to the UV-VIS sensors, the system can accommodate up to 8 additional sensors that are available from a third party and priced separately.

This plan includes pricing and details for a system equipped to measure conductivity, pH, temperature, and dissolved oxygen. Other additional sensors could be purchased and added if deemed necessary by the utility.

Where would the equipment be located?

In the case of Kanawha Falls PSD, the UV-VIS Full Monitoring System could be located in the water treatment plant since it is so close to the raw water intake. A small-diameter line or hose would run from the treatment plant to the intake pipe to pull raw water back to the controller where it would flow into the unit for sampling. The closer the end of the sampling line can be to the actual intake, the more accurately it will reflect the raw water that is actually entering the plant. This option would require the utility to purchase enough line to reach the intake as well as a small pump. The line and pump could be fairly small and inexpensive, as the

system only requires a minimum of 300-800 mL/min. of flow. The system also includes the Real Pump Clean System, which provides flow and automatic chemical cleaning of the sensors and reduces maintenance time.

This system would require a reliable electrical source, but it could likely be powered by the water treatment plant since it is so close.

What would the maintenance plan for the monitoring equipment entail?

The maintenance plan for the system would require about 2 hrs/month for scheduled maintenance tasks. It is also recommended that a monthly laboratory reference sample is taken to effectively calibrate the sensors.

The Smart-Sense Web Monitoring Service package costs an additional \$499/yr., but provides additional support and remote accessibility by Real Tech, and it is recommended. The Deuterium and Tungsten lamps would also need to be replaced every six months at a cost of \$740.

Describe the proposed sampling plan at the monitoring site.

The Full Scanning UV-VIS system continuously monitors raw water as it is pumped through the unit, and is capable of establishing baseline conditions that account for seasonal variability, which can help to reduce false alarms.

Describe the proposed procedures for data management and analysis.

The Real Tech monitoring system is capable of communicating with the treatment plant via Modbus, Ethernet, USB, or cell modem. It can be integrated with the treatment plant's SCADA system to provide real-time information about conditions at the intake and provides full remote monitoring.

It is also recommended that the utility take advantage of the Smart-Sense Web Monitoring service offered by Real-Tech to analyze and interpret data taken by the monitoring system. This consultation service requires an additional service fee, which is included in this quote.

APPENDIX C. COMMUNICATION PLAN TEMPLATE

Kanawha Falls PSD

PWSID: WV3301037

District: Beckley

Certified Operator: Carl King

Contact Phone Number: 304-632-1633

Contact Email Address: kfpsd_12@yahoo.com

Plan Developed On: July 1, 2016

ACKNOWLEDGMENTS:

This plan was developed by Kanawha Falls PSD to meet certain requirements of the Source Water and Assessment Protection Program (SWAPP) and the Wellhead Protection Program (WHPP) for the State of West Virginia, as directed by the federal Safe Drinking Water Act (SDWA) and state laws and regulations.

TABLE OF CONTENTS

INTRODUCTION.....C-1

TIERS REPORTING SYSTEM.....C-1

COMMUNICATION TEAM.....C-2

COMMUNICATION TEAM DUTIESC-2

INCIDENT / EVENT COMMUNICATION PROCEDURE.....C-3

TIERS FLOW CHART.....C-5

EMERGENCY SHORT FORMS.....C-6

EMERGENCY CONTACT INFORMATION.....C-9

PRESS RELEASE ATTACHMENTS.....C-10

INTRODUCTION

Legislative Rule 64CSR3 requires public water systems to develop a Communication Plan that documents how public water suppliers, working in concert with state and local emergency response agencies, shall notify state and local health agencies and the public in the event of a spill or contamination event that poses a potential threat to public health and safety. The plan must indicate how the public water supplier will provide updated information, with an initial notification to the public to occur no later than thirty minutes after the supplier becomes aware that the spill, release or potential contamination of the public water system poses a potential threat to public health and safety.

The public water system has responsibility to communicate to the public, as well as to state and local health agencies. This plan is intended to comply with the requirements of Legislative Rule 64CSR3, and other state and federal regulations.

TIERS REPORTING SYSTEM

This water system has elected to use the *Tiered Incident / Event Reporting System* (TIERS) for communicating with the public, agencies, the media, and other entities in the event of a spill or other incident that may threaten water quality. TIERS provides a multi-level notification framework, which escalates the communicated threat level commensurate with the drinking water system risks associated with a particular contamination incident or event. TIERS also includes a procedural flow chart illustrating key incident response communication functions and how they interface with overall event response / incident management actions. Finally, TIERS identifies the roles and responsibilities for key people involved in risk response, public notification, news media and other communication.

TIERS provides an easy-to-remember five-tiered **A-B-C-D-E** risk-based incident response communication format, as described below. Table 1 provides also associated risk levels.

A = Announcement. The water system is issuing an announcement to the public and public agencies about an incident or event that may pose a threat to water quality. Additional information will be provided as it becomes available. As always, if water system customers notice anything unusual about their water, they should contact the water system

B = Boil Water Advisory. A boil water advisory has been issued by the water system. Customers may use the water for showering, bathing, and other non-potable uses, but should boil water used for drinking or cooking.

C = Cannot Drink. The water system asks that users not drink or cook with the water at this time. Non-potable uses, such as showering, bathing, cleaning, and outdoor uses are not affected.

D = Do Not Use. An incident or event has occurred affecting nearly all uses of the water. Do not use the water for drinking, cooking, showering, bathing, cleaning, or other tasks where water can come in contact with your skin. Water can be used for flushing commodes and fire protection.

E = Emergency. Water cannot be used for any reason.

| Tier | Tier Category | Risk Level | Tier Summary |
|----------|----------------------------|------------|---|
| A | Announcement | Low | The water system is issuing an announcement to the public and public agencies about an incident or event that could pose a threat to public health and safety. Additional information will be provided as it becomes available. |
| B | Boil Water Advisory | Moderate | Water system users are advised to boil any water to be used for drinking or cooking, due to possible microbial contamination. The system operator will notify users when the boil water advisory is lifted. |

| | | | |
|----------|---------------------|----------------|--|
| C | Cannot Drink | High | System users should not drink or cook with the water until further notice. The water can still be used for showering, bathing, cleaning, and other tasks. |
| D | Do Not Use | Very High | The water should only be used for flushing commodes and fire protection until further notice. More information on this notice will be provided as soon as it is available. |
| E | Emergency | Extremely High | The water should not be used for any purpose until further notice. More information on this notice will be provided as soon as it is available. |

COMMUNICATION TEAM

The Communication Team for the water system is listed in the table below, along with key roles. In the event of a spill or other incident that may affect water quality, the water system spokesperson will provide initial information, until the team assembles (if necessary) to provide follow-up communication.

Water system communication team members, organizations, and roles.

| Team Member Name | Organization | Phone | Email | Role |
|------------------|-------------------------------|--------------|--------------------|------------------------|
| Rick Wagner | Kanawha Falls PSD | 304-632-1633 | kfpsd_12@yahoo.com | Primary Spokesperson |
| Carl King | Kanawha Falls PSD | 304-779-2600 | kfpsd_12@yahoo.com | Secondary Spokesperson |
| Roger Wagner | Kanawha Falls PSD | 304-640-2131 | rwagner@glbsm.com | Member |
| Damon Runyon | Gauley Bridge Fire Department | 304-632-1810 | Damon_47@yahoo.com | Member |

In the event of a spill, release, or other incident that may threaten water quality, members of the team who are available will coordinate with the management staff of the local water supplier to:

- Collect information needed to investigate, analyze, and characterize the incident/event
- Provide information to the management staff, so they can decide how to respond
- Assist the management staff in handling event response and communication duties
- Coordinate fully and seamlessly with the management staff to ensure response effectiveness

COMMUNICATION TEAM DUTIES

The communication team will be responsible for working cooperatively with the management staff and state and local emergency response agencies to notify local health agencies and the public of the initial spill or contamination event. The team will also provide updated information related to any contamination or impairment of the source water supply or the system's drinking water supply.

According to Legislative Rule 64CSR3, the initial notification to the public will occur no later than thirty minutes after the public water system becomes aware that the spill, release or potential contamination of the public water system poses a potential threat to public health and safety.

As part of the group implementing the Source Water Protection Plan, team members are expected to be familiar with the plan, including incident/event response and communication tasks. Specifically, team members should:

- Be knowledgeable on elements of the Source Water Protection Plan and Communication Plan
- Attend team meetings to ensure up-to-date knowledge of the system and its functions
- Participate in periodic exercises that “game out” incident response and communication tasks
- Help to educate local officials, the media, and others on source water protection

- Cooperate with water supplier efforts to coordinate incident response communication
- Be prepared to respond to requests for field investigations of reported incidents
- Not speak on behalf of the water supplier unless designated as the system's spokesperson

The primary spokesperson will be responsible for speaking on behalf of the water system to local agencies, the public, and the news media. The spokesperson should work with the management staff and the team to ensure that all communication is clear, accurate, timely, and consistent. The spokesperson may authorize and/or direct others to issue news releases or other information that has been approved by the system's management staff. The spokesperson is expected to be on call immediately when an incident or event which may threaten water quality occurs. The spokesperson will perform the following tasks in the event of a spill, release, or other event that threatens water quality:

- Announce which risk level (A, B, C, D, or E) will apply to the public notifications that are issued
- Issue news releases, updates, and other information regarding the incident/event
- Use the news media, email, social media, and other appropriate information venues
- Ensure that news releases are sent to local health agencies and the public
- Respond to questions from the news media and others regarding the incident/event
- Appear at news conferences and interviews to explain incident response, etc.

INCIDENT / EVENT COMMUNICATION PROCEDURE

The flow chart in this section illustrates how the water system will respond when it receives a report that a spill, release, or other contamination event may have occurred. Key elements of the flow chart are described below.

Communication with agencies, the public, and the media during threat incidents

Upon initial notification of the incident/event, system managers and staff will collect information and verify the need for further investigation. Only properly trained personnel will perform onsite investigations if permitted by emergency responders. If further investigation is warranted, and the initial facts support it, the water system spokesperson will issue a public communication statement consistent with the threat level. In addition, water system personnel and partners will be dispatched to conduct reconnaissance, a threat assessment, and a threat characterization, if present. This work may include:

- Verification of the incident/event type (spill, release, etc.)
- Location of incident/event
- Type of material(s) involved in spill, release, etc.
- Quantity of material involved
- Potential of the material to move, migrate, or be transported
- Relevant time factor(s) in the risk assessment (e.g., downstream movement rate)
- Overall level of risk to water system, whether low, moderate, high, or very high
- Development of the initial risk characterization


As the flow chart indicates, several iterative cycles will occur after the initial threat assessment, including communication with local agencies and the public, further investigation of the incident, possible implementation of the water system's contingency plan, and eventual elimination of the threat and a return to normal operations. Communication activities during this period will include:

- The initial release (i.e., **Announcement, Boil Water Advisory, Cannot Drink, Do Not Use, or Emergency**)
 - Sent to local health agencies, the public, and the news media within 30 minutes
- Notification of the local water system's source water protection and communication teams
 - If warranted by initial findings regarding the spill, release, or incident
- Notification of the WV Bureau of Public Health
 - As required
- Periodic information updates, as incident response information is received
- Updates to the applicable A-B-C-D-E advisory tier, as necessary

After the threat level is reduced and operations return to normal, the water system staff, as well as the communication and source water protection teams and their partners, will conduct a post-event review and

assessment. The purpose of the review is to examine the response to the incident, relevant communication activities, and overall outcomes. Plans and procedures may be updated, altered, or adapted based on lessons learned through this process.

TIERS FLOW CHART



EMERGENCY SHORT FORMS

Emergency Communication Information

| | Name | Phone Number | Email | |
|---|--|--|--------------------|-----------------|
| Designated spokesperson: | Rick Wagner | 304-632-1633 | kfpsd_12@yahoo.com | |
| Alternate spokesperson: | Carl King | 304-779-2600 | - | |
| Designated location to disseminate information to media: | Kanawha Falls PSD Office or the water treatment plant | | | |
| Methods of contacting affected residents: | <p>Kanawha Falls PSD primarily contacts affected residents about important information using local newspapers, posted notices, radio, and television. The water system staff are looking into the possibility of adopting an emergency notification system to facilitate communication with customers.</p> | | | |
| Media contacts: | Name | Title | Phone Number | Email |
| | WVNSTV | 59 News CBS Affiliate, Oak Hill, WV | 304-929-6420 | news@wvnstv.com |
| | WSAZ | News Channel 3 NBC Affiliate, Charleston, WV | 304-344-3521 | news@wsaz.com |
| | WOAYTV 50 | ABC Affiliate, Oak Hill, WV | 304-469-3361 | news@woay.com |

Emergency Services Contacts

| | Name | Emergency Phone | Alternate Phone | Email |
|--------------------------------|------------------------------------|-----------------|-----------------|-------|
| Local Police | Gauley Bridge Police Department | 911 | 304-632-2504 | - |
| Local Fire Department | Gauley Bridge Fire Department | 911 | 304-632-1810 | - |
| Local Ambulance Service | Jan Care General Ambulance Service | 911 | 304-632-1122 | - |

| | | | | |
|--|----------------------------------|--------------|--------------|---|
| | | | 304-779-2166 | |
| Hazardous Material Response Service | Boomer Volunteer Fire Department | 304-779-2763 | 304-574-3590 | - |

Sensitive Populations

| | | | | |
|--|----------------------------------|--|--|--------------------------------|
| Other communities that are served by the utility: | Gauley Bridge, Boomer, Alloy | | | |
| Major user/sensitive population notification: | Name | Emergency Phone | Alternate Phone | |
| | World Changers Christian Academy | 304-810-9222 | - | |
| | Boomer Baptist Church School | 304-442-8967 | - | |
| | Gauley Bridge Elementary School | 304-632-2661 | - | |
| EED District Office Contact: | Name | Phone | Email | |
| | John Stafford | 304-256-6666 EED Central Office 304-558-2981 | john.pb.stafford@wv.gov | |
| OEHS Readiness Coordinator | Warren Von Dollen | 304-356-4290 (main) 304-550-5607 (cell) | warren.r.vondollen@wv.gov | |
| Downstream Water Contacts: | Water System Name | Contact Name | Emergency Phone | Alternate Phone |
| | Armstrong PSD | Joe Burdett | Treatment Plant 304-442-5044 | Don Navarro 304-442-5647 |
| | WVAW-Montgomery District | Dave Peters | Treatment Plant 304-442-9728 | 304-340-2038 |
| | Community of Cedar Grove | Kenneth Barton | Treatment Plant 304-595-2991 | Utility Office 304-595-1841 |
| Are you planning on implementing the TIER system? | | | Yes | |

Key Personnel

| | Name | Title | Phone | Email |
|---|-------------|-----------------|--------------|--------------------|
| Key staff responsible for coordinating emergency response procedures? | Rick Wagner | Utility Manager | 304-632-1633 | kfpsd_12@yahoo.com |
| | Carl King | Chief Operator | 304-779-2600 | - |
| Staff responsible for keeping confidential PSSC information and releasing to emergency responders: | Rick Wagner | Utility Manager | 304-632-1633 | kfpsd_12@yahoo.com |
| | Carl King | Chief Operator | 304-779-2600 | - |

Emergency Response Information

| List laboratories available to perform sample analysis in case of emergency: | Name | Phone |
|---|--|---|
| | REIC Laboratory- Beaver, WV | 800-999-0105, 304-255-2500, info@reiclabs.com |
| | ALS Environmental- South Charleston, WV | 304-356-3168 |
| | WV State Laboratory, Environmental Chemistry Section- Charleston, WV | 304-965-2694 |
| Has the utility developed a detailed Emergency Response Plan in accordance with the Public Health Security Bioterrorism Preparedness and Response Pan Act of 2002? | | No |
| When was the Emergency Response Plan developed or last updated? | | N/A |

EMERGENCY CONTACT INFORMATION

State Emergency Spill Notification

1-800-642-3074

Office of Emergency Services

<http://www.wvdhsem.gov/>
Charleston, WV- (304) 558-5380

WV Bureau for Public Health Office of Environmental Health Services (OEHS)

www.wvdhhr.org/oehs

Readiness Coordinator- Warren Von Dollen

Phone; 304-356-4290

Cell; 304-550-5607

E-mail: warren.r.vondollen@wv.gov

Environmental Engineering Division Staff

Charleston, Central Office (304) 558-2981

Beckley, District 1 (304) 256-6666

St. Albans, District 2 (304) 722-0611

Kearneysville, District 4 (304) 725-9453

Wheeling, District 5 (304) 238-1145

Fairmont, District 6 (304) 368-2530

National Response Center - Chemical, Oil, & Chemical/Biological Terrorism

1-800-424-8802

WV State Fire Marshal's Office

1-800-233-3473

West Virginia State Police

1-304-746-2100

WV Watch – Report Suspicious Activity

1-866-989-2824

DEP Distance Calculator

<http://tagis.dep.wv.gov/pswcheck/>

PRESS RELEASE ATTACHMENTS

TIERS Levels A, B, C, D, and E

UTILITY ISSUED NOTICE – LEVEL A
PUBLIC WATER SYSTEM ANNOUNCEMENT
A WATER SYSTEM INVESTIGATION IS UNDERWAY

On _____ at ____:____ AM/PM, the _____ Water System began investigating an incident that may affect local water quality.

The incident involves the following situation at this location:

There are no restrictions on water use at this time. As always, if water system customers notice anything unusual about their water – such as abnormal odors, colors, sheen, etc. – they should contact the water system at _____.

At this time there is no need for concern if you have consumed or used the water.

Regular updates will be provided about this Announcement as water system staff continue their investigation. Again, there are no restrictions on water use at this time.

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL B
BOIL WATER ADVISORY
A BOIL WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water.
The areas that are affected are as follows:

☐ Entire Water System or ☐ Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST.** Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, bathing, and food preparation **until further notice**. Boiling kills bacteria and other organisms in the water.

What happened?

- The problem is related to _____

What is being done?

- The water system is taking the following action: _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when you no longer need to boil your water. We anticipate resolving the problem within _____ hours/days. For more information, please contact _____ at _____ or _____ at _____.

General guidelines on ways to lessen the health risk are available from the EPA Safe Drinking Water Hotline at 1 (800) 426-4791.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL C
“CANNOT DRINK” WATER NOTIFICATION
A LEVEL C WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water.
The areas that are affected are as follows:

☐ Entire Water System or ☐ Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER.** You can't drink the water, but you can use it for showering, bathing, toilet-flushing, and other non-potable purposes.
- **BOILING WILL NOT PURIFY THE WATER.** Do not drink the water, even if it is boiled. The type of contamination suspected is not removed by boiling.

What happened?

- The problem is related to _____

What is being done?

- The water system is taking the following action: _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when the water is safe to drink. We anticipate resolving the problem within _____ hours/days. For more information – or to report unusual water conditions such as abnormal odors, colors, sheen, etc. – please contact _____ at _____ or _____ at _____.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL D
“DO NOT USE” WATER NOTIFICATION
A LEVEL D WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water.
The areas that are affected are as follows:

☐ Entire Water System or ☐ Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER.** The water is contaminated.
- **DO NOT SHOWER OR BATHE IN THE WATER.** You can't use the water for drinking, showering, or bathing. It can be used for toilet flushing and firefighting.
- **BOILING WILL NOT PURIFY THE WATER.** Do not use the water, even if it is boiled. The type of contamination suspected is not removed by boiling.

What happened?

- The problem is related to _____

What is being done?

- The water system is taking the following action: _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when the water is safe to drink. We anticipate resolving the problem within _____ hours/days. For more information – or to report unusual water conditions such as abnormal odors, colors, sheen, etc. – please contact _____ at _____ or _____ at _____.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL E
EMERGENCY WATER NOTIFICATION
A LEVEL E WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water.
The areas that are affected are as follows:

☐ Entire Water System or ☐ Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER.** The water is contaminated.
- **DO NOT USE THE WATER FOR ANY PURPOSE!** You can't use the water for drinking, showering, or bathing, or any other use – not even for toilet flushing.
- **BOILING WILL NOT PURIFY THE WATER.** Do not use the water, even if it is boiled. The type of contamination suspected is not removed by boiling.

What happened?

- The problem is related to _____

What is being done?

- The water system is taking the following action: _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when the water is safe to drink. We anticipate resolving the problem within _____ hours/days. For more information – or to report unusual water conditions such as abnormal odors, colors, sheen, etc. – please contact _____ at _____ or _____ at _____.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

APPENDIX D. SINGLE SOURCE FEASIBILITY STUDY

Source Water Protection Plan

Contingency Plan and Feasibility Study

KANAWHA FALLS PSD

PWSID WV3301037
FAYETTE COUNTY

SEPTEMBER 2015

Prepared by:

Tetra Tech, Inc.
803 Quarrier Street, Suite 400
Charleston, WV 25314

In cooperation with Kanawha Falls PSD

A blue ink signature of Victor D'Amato over a horizontal line.
Victor D'Amato, PEA blue ink date '9/10/15' over a horizontal line.
Date

Contents

Background 1

Contingency Plan 1

 Responding to Water Shortage or Contamination Event..... 1

 Operation During Loss of Power 3

 Future Water Supply Needs..... 4

 Water Loss..... 5

 Early Warning Monitoring System 6

Single Source Feasibility Study 8

Tables

Table 1. Kanawha Falls PSD Water Shortage Response Capability..... 2

Table 2. Generator Capacity 3

Table 3. Future Water Supply Needs for Kanawha Falls PSD 4

Table 4. Water Loss Information..... 5

Table 5. Early Warning Monitoring System Capabilities..... 7

Appendices

Appendix A. Early Warning Monitoring System

Appendix B. Single Source Feasibility Study Matrices and Narrative

Background

To fulfill the requirements of Senate Bill 373 and Legislative Rule 64 CSR 3, Kanawha Falls Public Service District (PSD) has participated in a study to evaluate its existing contingency planning and feasibility of source water alternatives. This Contingency Planning and Feasibility Study report documents the results of the study and provides information about the utility's ability to prevent contaminants from entering the water system if possible, and sufficiently respond to an emergency if necessary. This report represents only a portion of the required elements of the Source Water Protection Plan for Kanawha Falls PSD. The information presented in this report will be included in the final Source Water Protection Plan.

Contingency Plan

The goal of contingency planning is to identify and document how the utility will prepare for and respond to any drinking water shortages or emergencies that may occur due to short and long term water interruption, or incidents of spill or contamination. Utilities should examine their capacity to protect their intake, treatment facility, and distribution system from contamination. They should also review their ability to use alternative sources, minimize water loss, meet future water demands, and operate during power outages. In addition, utilities should report the feasibility of establishing an early warning monitoring system. The following sections address these considerations and present information required for the source water protection plan.

Responding to Water Shortage or Contamination Event

Isolating or diverting any possible contaminant from the intake for a public water system is an important strategy in the event of an emergency. One commonly used method of diverting contaminants from an intake is establishing booms around the intake. This can be effective, but only for contaminants that float on the surface of the water. Alternatively, utilities can choose to pump floating contaminants from the water or chemically neutralize the contaminant before it enters the treatment facility.

Public utilities using surface sources should be able to close the intake by one means or another. However, depending upon the system, methods for doing so could vary greatly and includes closing valves, lowering hatches or gates, raising the intake piping out of the water, or shutting down pumps. Systems should have plans in place in advance as to the best method to protect the intake and treatment facility. Utilities may benefit from turning off pumps and, if possible, closing the intake opening to prevent contaminants from entering the piping leading to the pumps. Utilities should also have a plan in place to sample raw water to identify the movement of a contaminant plume and allow for maximum pumping time before shutting down an intake (See Early Warning Monitoring System). The amount of time that an intake can remain closed depends on the water infrastructure and should be determined by the utility before an emergency occurs. The longer an intake can remain closed in such a case, the better.

Raw and treated water storage capacity in the event of such an emergency also becomes extremely important. Storage capacity can directly determine how effectively a water system can respond to a contamination event and how long an intake can remain closed. Information regarding the water shortage response capability of Kanawha Falls PSD is provided in **Table 1**.

Statewide initiatives for emergency response, including source water related incidents, are being developed. These include the West Virginia Water/Wastewater Agency Response Network (WV WARN, see <http://www.wvwarn.org/>) and the Rural Water Association Emergency Response Team (see <http://www.wvrwa.org/>). Kanawha Falls PSD has analyzed its ability to effectively respond to emergencies and this information is also provided in **Table 1**.

Table 1. Kanawha Falls PSD Water Shortage Response Capability

| | |
|---|---|
| Can the utility isolate or divert contamination from the intake or groundwater supply? | Yes |
| Describe the utility's capability to isolate or divert potential contaminants: | The utility has access to booms they can use to isolate the raw water intake from surface contaminants. WVA Manufacturing, which is located just downstream from the treatment plant, also has booms available. |
| Can the utility switch to an alternative water source or intake that can supply full capacity at any time? | No |
| Describe in detail the utility's capability to switch to an alternative source: | The utility has no means of switching to an alternative source of raw water. |
| Can the utility close the water intake to prevent contamination from entering the water supply? | Yes |
| How long can the intake stay closed? | If the tanks were full when the intake went closed, the water system could operate for 1.7 days. This is partially dependent on the ability of Gauley River PSD, who is supplied by Kanawha Falls, to conserve their water. |
| Describe the process to close the intake: | The operator can manually close a valve to shut off the intake and prevent contaminated raw water from entering the plant. |
| Describe the raw and treated water storage capacity of the water system: | <p>Kanawha Falls PSD has 6 treated water storage tanks and 2 booster pump stations (BPS).</p> <p>Boomer Tank- 200,000 gallons</p> <p>Falls View Tank #1- 300,000 gal.</p> <p>Falls View Tank #2- 300,000 gal.</p> <p>Gauley Bridge High Tank- 107,000 gal.</p> <p>Gauley Bridge Low Tank- 223,000 gal.</p> <p>Charlton Heights Tank- 105,000 gal.</p> <p>Total= 1,235,000 gal. treated water storage</p> <p>The utility does not have any raw water storage.</p> |
| Is the utility a member of WVRWA Emergency Response Team? | The utility is a member of West Virginia Rural Water Association (WVRWA) but not the WVRWA Emergency Response Team. |
| Is the utility a member of WV-WARN? | No |

| | |
|--|--|
| List any other mutual aid agreements to provide or receive assistance in the event of an emergency: | The utility has an informal mutual aid agreement with West Virginia American Water in Montgomery, who provided them with water tankers during the 2015 train derailment. |
|--|--|

Operation During Loss of Power

Kanawha Falls PSD analyzed and examined its ability to operate effectively during a loss of power. This involved ensuring a means to supply water through treatment, storage, and distribution without creating a public health emergency. Information regarding the utility's capacity for operation during power outages is summarized in **Table 2**.

Table 2. Kanawha Falls PSD Generator Capacity

| | | |
|---|---|--|
| What is the type and capacity of the generator needed to operate during a loss of power? | The Kanawha Falls water treatment plant requires a 250kW generator, and the two booster stations each require a 50 kW generator to operate during a power outage. They currently do not own any generators, and plan on renting them as needed. | |
| Can the utility connect to generator at intake/wellhead? If yes, select a scenario that best describes system. | No. The raw water intake is located directly adjacent to the treatment plant and the pumps are powered by the plant, so a generator is not necessary. | |
| Can the utility connect to generator at treatment facility? If yes, select a scenario that best describes system. | Yes. The treatment plant is fully wired to be connected to a generator that will be rented or borrowed during a power outage. | |
| Can the utility connect to a generator in distribution system? If yes, select a scenario that best describes system. | Yes. Both booster pump stations are fully wired for a generator that will be rented or borrowed during a power outage. | |
| Does the utility have adequate fuel on hand for the generator? | No. Kanawha Falls PSD does not have any on-site fuel storage. | |
| What is your on-hand fuel storage and how long will it last operating at full capacity? | Gallons | Hours |
| | None. | N/A |
| Provide a list of suppliers that could provide generators and fuel in the event of an emergency: | Supplier | |
| | Generator | Contact Information |
| | Mountaineer Generator- Elkins, WV | (304) 636-0011 or (724) 324-2122 |

| | | | |
|--|------------------|--|----------------|
| | Generator | Walker Caterpillar- Belle, WV | (304) 949-6400 |
| | Fuel | West Virginia Division of Highways- Kanawha Falls, WV | (304) 647-7450 |
| | Fuel | Sunoco- Montgomery, WV | (304) 442-8900 |
| Does the utility test the generator(s) periodically? | | N/A | |
| Does the utility routinely maintain the generator? | | N/A | |
| If no scenario describing the ability to connect to generator matches the utility's system or if utility does not have ability to connect to a generator, describe plans to respond to power outages: | | The utility has had no problem renting generators when they needed them in the past and plans to rent them again in the event of a power outage. | |

Future Water Supply Needs

When planning for potential emergencies and developing contingency plans, a utility needs not only to consider their current demands for treated water but also account for likely future needs. This could mean expanding current intake sources or developing new ones in the near future. This can be an expensive and time consuming process, and any water utility should take this into account when determining emergency preparedness. Kanawha Falls PSD has analyzed its ability to meet future water demands at current capacity, and this information is included in **Table 3**.

Table 3. Future Water Supply Needs for Kanawha Falls PSD

| | |
|--|--|
| Is the utility able to meet water demands with the current production capacity over the next 5 years? If so, explain how you plan to do so. | Yes- The utility does not expect any significant changes in demand over the next 5 five years, and the treatment plant is currently operating at an average of 50%-60% of capacity. No water line extensions are planned for the next five years, and there is no expected increase in population. The water system's opinions concerning the demand for the next five years are generally supported by population trends projected based on US Census Bureau 2000 and 2010 data. According to the 2005 Interim State Population Projections ⁽¹⁾ , WV as a whole will see a population decline between 2010 and 2030. In addition, researchers at the WVU College of Business and Economics specifically project that populations within Fayette County will decrease from population of 46,039 in 2010 to a projected population of 44,611 in 2020 ⁽²⁾ . Census data and projections cannot account for increases in daily demand due to water line extensions. If in the future water line extension projects are proposed the daily demands will be |
|--|--|

| | |
|--|--|
| | reassessed to determine if the source and treatment facilities can support increased demand. |
| If not, describe the circumstances and plans to increase production capacity: | N/A |

(1) US Department of Commerce, United State Census Bureau. 2005 Interim State Population Projections. Table 1.

<http://www.census.gov/population/projections/data/state/projectionsagesex.html>. Accessed June 10, 2015.

(2) Christiadi, Ph.D., Deskins, John, Ph.D., Lego, Brian. WVU College of Business and Economics, Bureau of Business and Economic

Research. March 2014. WVU Research Corporation. <http://be.wvu.edu/bber/pdfs/BBER-2014-04.pdf> Accessed June 10, 2015.

Water Loss

In any public water system there is a certain percentage of the total treated water that does not reach the customer. Some of this water is used in treatment plant processes such as back washing filters or flushing piping, but there is usually at least a small percentage that goes unaccounted for. This can include unmetered uses, leaks, and other losses. To measure and report on this unaccounted for water, a public utility must use the same method used in the Public Service Commission's rule, *Rules for the Government of Water Utilities*, 150CSR7, section 5.6. The rule defines unaccounted for water as the volume of water introduced into the distribution system less all metered usage and all known non-metered usage which can be estimated with reasonable accuracy.

Metered usages are most often those that are distributed to customers. Non-metered usages that are being estimated include uses such as by the fire departments for fires or training, un-metered bulk sells, flushing to maintain the distribution system, and water used for backwashing filters and cleaning settling basins. By subtracting the metered and non-metered uses from the total raw water pumped, the utility can calculate unaccounted for water. Note: To complete annual reports submitted to the PSC, utilities typically account for known water main breaks by estimating the amount of water lost. However, for the purposes of the source water protection plan, any water lost due to leaks, even if the system is aware of how much water is lost at a main break, is not considered a use. Water lost through leaks and main breaks cannot be controlled during a water shortage or other emergency and should be included in the calculation of percentage of water loss for purposes of the source water protection plan. The data in **Table 4** is taken from the most recently submitted Kanawha Falls PSD PSC Annual Report.

Table 4. Annual Water Loss Information*

| | | |
|---|---|-------------|
| Total Water Pumped (gal) | | 204,000,000 |
| Total Water Purchased (gal) | | 0 |
| Total Water Pumped and Purchased (gal) | | 204,000,000 |
| Water Loss Accounted for Except Main Leaks (gal) | Mains, Plants, Filters, Flushing, etc. | 0 |
| | Fire Department | 0 |
| | Back Washing | 0 |

| | | |
|--|--------------------------------|--|
| | Blowing Settling Basins | 0 |
| Total Water Loss Accounted For Except Main Leaks | | 0 |
| Water Sold- Total Gallons (gal) | | 182,500,000 |
| Unaccounted For Lost Water (gal) | | 21,489,000 |
| Water lost from main leaks (gal) | | 11,000,000 |
| Total gallons of Unaccounted for Lost Water and Water Lost from Main Leaks (gal) | | 21,500,000 |
| Total Percent Unaccounted For Water and Water Lost from Main Leaks (gal) | | 10.54% |
| If total percentage of Unaccounted for Water is greater than 15%, please describe any measures that could be taken to correct this problem: | | The utility has been successful in keeping their total water loss under 15% and plans to continue to manage their system as efficiently as possible. |

*Water loss data is taken from the 2013 Public Service Commission Annual Report for Kanawha Falls PSD. The 2013 report was used because the 2014 report did not contain information about water production or loss.

Early Warning Monitoring System

Public water utilities are required to provide an examination of the technical and economic feasibility of implementing an early warning monitoring system. Implementing an early warning monitoring system may be approached in different ways depending upon the water utility's resources and threats to the source water. A utility may install a continuous monitoring system that will provide real time information regarding water quality conditions. This would require utilities to analyze the data in order to establish what condition is indicative of a contamination event. Continuous monitoring provides results for a predetermined set of parameters. The more parameters being monitored, the more sophisticated the monitoring equipment will be. When establishing a continuous monitoring system, the utility should consider the logistics of placing and maintaining the equipment, and receiving output data from the equipment.

Alternately, or in addition, a utility may pull periodic grab samples on a regular basis, or in case of a reported incident. The grab samples may be analyzed for specific contaminants. A utility should examine their Potential Sources of Significant Contamination (PSSCs) to determine what chemical contaminants could pose a threat to the water source. If possible, the utility should plan in advance how those contaminants will be detected. Consideration should be given for where samples will be collected, the preservation and hold times for samples, available laboratories to analyze samples, and costs associated with the sampling event. Regardless of the type of monitoring (continuous or grab), utilities should collect samples for their source throughout the year to better understand the baseline water quality conditions and natural seasonal fluctuations. Establishing a baseline will help determine if changes in the water quality are indicative of a contamination event and inform the needed response.

Every utility should establish a system or process for receiving or detecting chemical threats with sufficient time to respond to protect the treatment facility and public health. All approaches to receiving and responding to an early warning should incorporate communication with facility owners and operators, with state and local emergency response agencies, with surrounding water utilities, and with the public. Communication plays an important role in knowing how to interpret data and how to respond.

Kanawha Falls PSD has analyzed its ability to monitor for and detect potential contaminants that could impact its source water. Information regarding this utility's early warning monitoring system capabilities can be found in **Table 5** and in **Appendix A**.

Table 5. Early Warning Monitoring System Capabilities

| | | |
|---|--|--|
| Does your system currently receive spill notifications from a state agency, neighboring water system, local emergency responders, or other facilities? If yes, from whom do you receive notices? | <p>Yes. Kanawha Falls PSD has received notices about possible contamination from Brookfield Energy, who manages the hydro-electric plants upstream.</p> <p>The have also received notices from the West Virginia Division of Homeland Security and Emergency Management</p> | |
| Are you aware of any facilities, land uses, or critical areas within your protection areas where chemical contaminants could be released or spilled? | <p>Yes. The utility's primary concerns are the hydro-electric energy plants that operate immediately upstream from the intake. The plants have had issues in the past but maintain regular communication with the operators at Kanawha Falls about any accidents or spills that may occur.</p> | |
| Are you prepared to detect potential contaminants if notified of a spill? | <p>No</p> | |
| List laboratories (and contact information) on whom you would rely to analyze water samples in case of a reported spill. | <p>Laboratories</p> | |
| | <p>Name</p> | <p>Contact</p> |
| | <p>REIC Laboratory- Beaver, WV</p> | <p>800-999-0105, (304) 255-2500, info@reiclabs.com</p> |
| | <p>ALS Environmental- South Charleston, WV</p> | <p>(304) 356-3168</p> |
| | <p>WV State Laboratory, Environmental Chemistry Section- Charleston, WV</p> | <p>(304) 965-2694</p> |
| Do you have an understanding of baseline or normal conditions for your source water quality that accounts for seasonal fluctuations? | <p>Yes - The utility tests daily for pH, turbidity, chlorine, fluoride, and alkalinity. They have an understanding of normal baseline conditions for their raw water source.</p> | |
| Does your utility currently monitor raw water (through continuous monitoring or periodic grab samples) at the surface | <p>No. See Form B in Appendix A.</p> | |

| | | | | |
|--|--------------------------|--|--|---|
| water intake or from a groundwater source on a regular basis? | | | | |
| Provide or estimate the capital and O&M costs for your proposed early warning monitoring system or upgraded system. | Monitoring System | YSI EXO 2 (Table B-1) | Hach sc1000 (Table B-2) | Real Tech Full Scanning Monitoring System (Table B-3) |
| | Capital | Total Capital Cost- \$19,000 | Approximate Capital Cost- \$18,907 | Approximate Capital Cost- \$24,155 |
| | Yearly O & M | Parts and calibration- Approximately \$1,000 Data management and telemetry- \$1,000 | Full service contract with Hach Service Representative- \$2,258 Online Viewer-\$600 | Replacement Lamps- \$1,480 Smart-Sense Monitoring Service- \$499 |
| Do you serve more than 100,000 customers? If so, please describe the methods you use to monitor at the same technical levels utilized by ORSANCO. | | No | | |

Single Source Feasibility Study

If a public water utility's water supply plant is served by a single-source intake in a surface water source of supply or a surface water influenced source of supply, the submitted source water protection plan must also include an examination and analysis of the technical and economic feasibility of developing alternative sources of water to provide continued safe and reliable public water service in the event its primary source of supply is detrimentally affected by contamination, release, spill event or other reason. These alternatives may include a secondary intake, two days of raw or treated water storage in addition to what is currently stored to meet water system design standards, interconnection with neighboring systems, or other options identified on a local level. Note that a secondary intake must draw water supplies from a substantially different location on the same water source, or from an entirely different water source.

To accomplish this requirement, the utility has examined existing and possible alternatives and ranked them by their technical, economic, and environmental feasibility according to the West Virginia Department of Health and Human Resources Bureau for Public Health (WVBPH) feasibility study guide. This guide provides several criteria to consider for each category, organized in a Feasibility Study Matrix. By completing the Feasibility Study Matrix, the utility has documented the process used to examine the feasibility of each alternative, and has generated scores that compare the alternatives. The Feasibility Study Matrix is attached as **Appendix B**.

In addition to the Feasibility Study Matrix spreadsheet, a brief narrative is also included in **Appendix B** that identifies one or more feasible alternative, provides a summary of data used to make this determination, and briefly summarizes the results of the matrix.

Appendix A. Early Warning Monitoring System

Form B - Proposed Early Warning Monitoring Systems

Kanawha Falls PSD

Primary Surface Water Source:

There are many possible solutions for designing and installing an early warning monitoring system. Over time, this technology changes and improves and it is difficult to determine the type of equipment that will be useful and effective in the long term. This plan is a proposed system that would work for Kanawha Falls PSD using current technology and the current plant and intake configuration.

The primary raw water source for Kanawha Falls PSD is the Kanawha River and the intake is located directly in front of the water treatment plant on the riverbank, about 150' away.

| B-1. YSI EXO 2 Monitoring System Proposal |
|---|
| Describe the type of early warning detection equipment that could be installed, including the design. |
| <p>This plan uses the YSI EXO 2 Multiport Sonde, which can accommodate 6 different sensors and has an automatic wiper mechanism to remove biofouling from the sensor tips, which reduces maintenance time. The sonde is built to be resilient and low maintenance, and is capable of providing online water quality monitoring that can be transmitted real time to a designated PC or website that can be accessed by any designated user.</p> <p>The sonde can hold up to 6 sensors, but this plan recommends 4 of the more basic sensors that would be sufficient to detect any sudden shifts in water quality in any West Virginia stream or river. These sensors would include: conductivity/temperature, optical dissolved oxygen, pH, and fluorescent dissolved organic matter (fDOM). The fDOM sensor could potentially detect petroleum products in the water but is not entirely reliable for this purpose. At this time, YSI does not make a sensor for petroleum products for the EXO 2 but likely will in the future, at which time it is recommended that the utility purchase it. Other sensors could be purchased in the future as well if deemed necessary by the utility.</p> |
| Where would the equipment be located? |
| <p>The sonde would be attached to the intake pipe itself, which extends only a few feet into the Kanawha River. This would provide a stable foundation for the equipment and also ensure that the device is able to sample the water that is actually entering the intake pipe and not missing potential contaminants because it is located on the wrong side of the stream or too far from the intake. The suggested method of mounting the sonde involves drilling holes in a PVC pipe, capping the end, inserting the sonde and attaching to the</p> |

intake pipe structure using brackets or chains. This will protect the sensor from debris and hide it from view somewhat.

The sonde would be hardwired to the YSI Storm 3 data analysis/telemetry system. Since the Kanawha Falls PSD water treatment plant is so close to the intake, the Storm 3 could be located in the plant itself. If this was not possible and it needed to be located on the bank closer to the intake, the unit is contained in a waterproof case and comes with a solar photovoltaic panel capable of powering both the data analysis unit and the sonde, so long as the sonde is hardwired to the Storm 3. The device can be battery powered as well if this is not an option.

What would the maintenance plan for the monitoring equipment entail?

The maintenance plan for the system would involve replacing the dissolved oxygen sensor cap, replacing the pH electrode cap, and purchasing pH, turbidity, and conductivity calibration solution on a yearly basis. The sonde itself is designed to last from 5-10 years and should be inspected and calibrated once a month.

In addition, there is a recurring yearly fee associated with the real-time data/telemetry package for managing the website and data analysis.

Describe the proposed sampling plan at the monitoring site.

The sonde can be programmed to take regular measurements at any intervals defined by the operator or user. These measurements can also be taken in bursts, averaged over a period of time, or modified automatically as water quality levels change. Data is stored in the Storm 3 and transmitted to the plant computer as it is recorded. This information can be transmitted wirelessly via a cellular modem. The cellular transmitter is powerful enough to work even in areas with poor cell reception.

Describe the proposed procedures for data management and analysis.

The Storm 3 package includes data management software that can generate data reports and presentations and allow the user to modify and adjust sampling schedules remotely from the plant.

The sonde can be programmed to alert the user when any of the water quality parameters exceeds a user-defined level. This will allow the operator to program the system to notify them when their previously observed baseline conditions are exceeded in time for them to shut down the pumps and close off the intake. The operator can receive alerts via text message and email at the treatment plant computer or any designated cell phone.

B-2. Hach sc1000 Monitoring System Proposal

Describe the type of early warning detection equipment that could be installed, including the design.

The Hach sc1000 online monitoring system, which includes a controller, back panel, display module, and trough. Raw water is pumped into the trough from the source where it can be sampled in real time. The probe module can accommodate up to 6 sensors, which means it can monitor up to 6 parameters at once. This plan suggests the following sensors: conductivity, pH, turbidity, and dissolved oxygen. Hach can also supply a sensor to detect oil in water, which would cost an additional \$18,414.00 and would possibly be a good investment for any water system if sufficient funds were available. This sensor is not included in the quoted capital cost. There are several other probes for other parameters that are available from Hach, and these could be purchased as deemed necessary by the utility.

Where would the equipment be located?

The sc1000 Controller, back panel, and trough could be located in the plant itself. A small diameter line would run out from the plant the length of the intake pipe to pull raw water back to the controller where it would flow into the trough for sampling. The closer this sampling line can be to the actual intake, the more accurately it will reflect the raw water that is actually entering the plant. This option would require the utility to purchase a line or hose long enough to reach the intake pipe and a small pump. The line and pump could be fairly low- tech and inexpensive, as the sc1000 only requires a minimum of 900 mL/min. of flow.

The controller will be equipped with the MODBUS advanced communications/networking unit, which can transmit readings in real time directly to the SCADA system in the treatment plant to alert the operators in any change in baseline water quality. The sc1000 can either be hardwired to the computer at the treatment plant or it can use a cellular modem to transmit the data if there is sufficient cellular signal.

What would the maintenance plan for the monitoring equipment entail?

The maintenance plan for the system would entail a yearly maintenance contract with the manufacturer. A Hach Service Representative would regularly service the monitoring equipment. This service would take care of all parts, labor, and preventative maintenance and would include 2-3 scheduled maintenance visits per year.

Describe the proposed sampling plan at the monitoring site.

The sc1000 monitors the quality of water flowing through the trough in real time, and can transmit this data back to the plant as it is collected. The actual timing of the sampling plan could be determined by the utility.

Describe the proposed procedures for data management and analysis.

It is recommended that the utility purchase the Hach Universal Data Gateway software, which would help to process and analyze the incoming information into easily interpreted reports. The price of this software is included in the rough capital cost.

B-3. Real Tech Full Scanning UV-VIS Monitoring System

Describe the type of early warning detection equipment that could be installed, including the design.

This plan utilizes the Real Tech Full Scanning UV-VIS monitoring system, which provides full ultraviolet/visible scanning for organics and other specific parameters that may indicate a contamination event. The included PC Controller is pre-loaded with the software needed to store and process this information to establish a “normal” or “baseline” set of conditions for the raw water source. In addition to the UV-VIS sensors, the system can accommodate up to 8 additional sensors that are available from a third party and priced separately.

This plan includes pricing and details for a system equipped to measure conductivity, pH, temperature, and dissolved oxygen. Other additional sensors could be purchased and added if deemed necessary by the utility.

Where would the equipment be located?

In the case of Kanawha Falls PSD, the UV-VIS Full Monitoring System could be located in the water treatment plant since it is so close to the raw water intake. A small-diameter line or hose would run from the treatment plant to the intake pipe to pull raw water back to the controller where it would flow into the unit for sampling. The closer the end of the sampling line can be to the actual intake, the more accurately it will reflect the raw water that is actually entering the plant. This option would require the utility to purchase enough line to reach the intake as well as a small pump. The line and pump could be fairly small and inexpensive, as the system only requires a minimum of 300-800 mL/min. of flow. The system also includes the Real Pump Clean System, which provides flow and automatic chemical cleaning of the sensors and reduces maintenance time.

This system would require a reliable electrical source, but it could likely be powered by the water treatment plant since it is so close.

What would the maintenance plan for the monitoring equipment entail?

The maintenance plan for the system would require about 2 hrs/month for scheduled maintenance tasks. It is also recommended that a monthly laboratory reference sample is taken to effectively calibrate the sensors.

The Smart-Sense Web Monitoring Service package costs an additional \$499/yr., but provides additional support and remote accessibility by Real Tech, and it is recommended. The Deuterium and Tungsten lamps would also need to be replaced every six months at a cost of \$740.

Describe the proposed sampling plan at the monitoring site.

The Full Scanning UV-VIS system continuously monitors raw water as it is pumped to through the unit, and is capable of establishing baseline conditions that account for seasonal variability, which can help to reduce false alarms.

Describe the proposed procedures for data management and analysis.

The Real Tech monitoring system is capable of communicating with the treatment plant via Modbus, Ethernet, USB, or cell modem. It can be integrated with the treatment plant's SCADA system to provide real-time information about conditions at the intake and provides full remote monitoring.

It is also recommended that the utility take advantage of the Smart-Sense Web Monitoring service offered by Real-Tech to analyze and interpret data taken by the monitoring system. This consultation service requires an additional service fee, which is included in this quote.

Single Source Alternatives Feasibility Study

KANAWHA FALLS PSD

PWSID: WV3301037

PURPOSE

This Source Water Alternatives Feasibility Study (the Study) is prepared in accordance with legislative rule 64CSR3. The rule provides for numerous source water protection planning activities. As part of these activities, if a secondary source of water supply is not available, public water systems (PWSs) are required to prepare a study to determine the technical and economic feasibility of the following options to provide continued water service in the event the source water becomes contaminated. The options include:

- Constructing or establishing a secondary or backup intake which would draw water supplies from a substantially different location or water source;
- Constructing additional raw water storage capacity and/or treated water storage capacity to provide at least two days of system storage based on the plant's maximum level of production experience in the last year;
- Creating or constructing an operation interconnection(s) between PWS with other PWS plants or another PWS to allow the utility to receive its water from a different source of supply;
- Any other alternative which is available to the PWS to secure safe and reliable alternative water supply.

If one or more of the above options is determined to be feasible, the PWS is required to provide additional detail on the costs, risks and benefits of implementing each feasible alternative.

This Study utilizes the matrix provided by the West Virginia Department of Health and Human Resources, Bureau for Public Health to determine the feasibility of the alternatives for the Kanawha Falls Public Services District (PSD). The matrix provides a systematic method of evaluating alternatives using numerous factors and a system to rank the economic, technical and environmental feasibility of each alternative.

SYSTEM DESCRIPTION

The Kanawha Falls PSD provides water service to approximately 2,700 people. Located in Fayette County, the PWS uses the Kanawha River as its raw water supply. **Figure 1** presents the location of the PWS. The design capacity of the WTP is 1.44 MGD and the WTP uses pre-sedimentation, sedimentation, soda-ash treatment and fluoridation to treat the water to potable standards. **Table 1** below provides a summary of the recent demands in the Kanawha Falls system.

Table 1. Kanawha Falls PSD Capacity and Demands

| Parameter | Value |
|--|-------|
| 2014 Average Day Demand (MGD) | 0.736 |
| 2014 Maximum Day Demand (MGD) | 1.181 |
| WTP Capacity (MGD) | 1.44 |
| WTP Utilization at Maximum Day Demand | 82% |
| MDD to ADD Ratio ⁽¹⁾ | 1.60 |

(1) Ratio Calculated using Maximum Daily Demand (MDD)/Average Daily Demand (ADD)

Storage in the Kanawha Falls system is provided by elevated storage tanks throughout the distribution system. **Table 2** provides a summary of the tanks.

Table 2. City of Kanawha Falls Storage

| Name | Type | Volume (gallons) |
|-------------------------------------|----------|------------------|
| ST006 - Boomer Tank | Elevated | 200,000 |
| ST007 - Falls View Tank 2 | Elevated | 300,000 |
| ST005 - Falls View Tank 1 | Elevated | 300,000 |
| ST003 - Gauley Bridge (high) | Elevated | 107,000 |
| ST002 - Gauley Bridge (low) | Elevated | 223,000 |
| ST004 - Charlton Heights | Elevated | 105,000 |
| Total | | 1,235,000 |
| 2014 ADD (MGD) | | 0.736 |
| Days Storage | | 1.68 days |

Currently Kanawha Falls does not meet the two day average day demand requirement. Given the relatively sprawling, non-looped nature of the distribution system it is unlikely the storage tanks can provide water beyond their specific supply zones. In the event of a WTP outage the higher elevation tanks will likely be at the highest risk of emptying first.




Figure 1. Kanawha Falls PSD Location Map

ALTERNATIVES

The alternatives evaluated are based on matching the capacity of the Kanawha Falls WTP. This will provide a common level of service among all alternatives. **Table 3** below provides the basis for sizing each alternative:

Table 3. Alternatives – Sizing Basis

| Alternative | Backup Intake | Raw Storage | Treated Storage | Interconnect |
|--------------|---------------|--------------------------|--------------------------|--------------|
| Basis | Max day | 2 days of max day demand | 2 days of max day demand | Average day |
| Value | 1.44 MGD | 2.88 MG | 2.88 MG | 0.897 MGD |

Cost estimates were developed based on a conceptual analysis of each alternative. All costs were reviewed for accuracy and compared with actual costs of similar projects and RSMeans CostWorks 2014. The estimates include materials, installation and contractor's overhead and profit. The estimates are also based on the following assumptions and considerations:

- Piping is priced as mechanical joint ductile iron unless noted otherwise, and includes provisions for road crossings, aerial crossings and site restoration.
- Raw water and treated water storage tanks are priced as steel ground tanks with site work and installation included.
- Pumps are sized and priced based on conceptual level estimates of the required pumping conditions (flow and total dynamic head).
- Precast concrete vaults and metal pump enclosures are sized to house the estimated number of pumps required along with HVAC, electrical, and controls equipment.
- Electrical and controls costs are estimated at 10% of the overall facility costs including pumps.
- Site work is estimated as a lump sum cost based on the approximate size of the disturbed area and other factors that affect level of effort (i.e. whether or not the site is within the 100-yr floodplain).
- Estimates include a 15% engineering allowance and a 30% contingency.
- For purposes of this comparative analysis, costs for land acquisition were estimated at an average \$70,000 per acre. This value was used consistently for each alternative and was selected as an average cost to account for unknown site specific variables (e.g. land and structure values, potential remediation costs, acquisition services, etc.).

All capital costs are annualized over a twenty year period using a 2.5% interest rate and 0.50% closing costs.

O&M cost estimates are developed based on the specific operational requirements for each alternative and include labor and materials. Estimates of power consumption of pumps are based on pump size, number of pumps, and estimated hours of operation. O&M tank estimates assume the exterior and interior are repainted every ten years and the raw water tanks are cleaned annually and treated water tanks cleaned every 5 years.

Backup Intake

The nearest water body that could potentially supply the WTP is Loop Creek in Deepwater, WV located across the Kanawha River from the WTP. Further investigation is required to verify that this water body can support the WTP capacity. This alternative requires about 6,800 feet of 12-inch pipe and an intake structure and pump station.

Raw Water Storage

The raw water storage alternative includes installing a 3.0 MG steel ground storage tank on land adjacent to the WTP site. The tank would require increasing the size of the pumps at the intake structure to fill the tank and installing an additional set of pumps to transfer raw water from the tank to the WTP. Portions of the proposed tank site are within the 100 year flood plain, requiring additional site work and measures to compensate for flood storage.

Treated Water Storage

Like the raw water storage alternative, treated water tankage would be located adjacent to the WTP and have a similar size and configuration without requiring modifications to the intake pumps. Providing additional treated water storage could present some operational challenges for the PWS in meeting the 20% daily turnover requirement (§64-77-9.4). With full tanks, the PWS may be faced with having to drain water during periods of low demand to meet the turnover requirement, resulting in an increase in non-revenue water for the system. This tank would also be located in the 100 year flood plain, and would require additional site work and measures to compensate for flood storage.

Interconnection

The nearest PWS with available supply for Kanawha Falls PSD is the WV American Water New River WTP in Anstead. This project would require approximately 88,000 feet of 10-inch pipe. However, with the elevation difference between the two systems pumps are not required. It is important to note that this WTP uses the New River as a source which is a tributary of the Kanawha River. If a pollution event were to affect the New River WTP, it would not be able to provide service to Kanawha Falls.

FEASIBILITY DETERMINATION

The attached matrix and sub-schedules (**Tables 4, 5, 6, and 7**) present the feasibility rankings of the alternatives. The interconnection with WV American Water does not rank high mostly due to the cost of extending a line from Kanawha Falls to Anstead.

Treated water storage is a possible alternative but adding additional volume would create potential operational issues associated with having to maintain a 20% turnover in volume and increasing nonrevenue water.

A backup intake on Loop Creek ranks as a feasible alternative having both a low cost and a relatively high technical score. However, its viability depends upon verification of whether there is sufficient flow to support Kanawha Falls' demands.

The highest ranked alternative is constructing raw water storage on the available land adjacent to the WTP site.

Table 4. Feasibility Matrix

| Water Management Strategy Description | Economic Criteria | | | | | Technical Criteria | | | | | | | Environmental Criteria | | | | | | Final Score | Capital Cost | Comments |
|---------------------------------------|---------------------------------|---------------|-------|---------|----------------|--------------------|-------------|------------|----------------------------|-------|---------|----------------|------------------------|-------------------|--------------------|-------|---------|----------------|-------------|--------------|---|
| | 45% | | | | | 45% | | | | | | | 10% | | | | | | 100% | | |
| | Operation and Maintenance Costs | Capital Costs | Total | Total % | Weighted Total | Permitting | Flexibility | Resilience | Institutional Requirements | Total | Total % | Weighted Total | Environmental Impacts | Aesthetic Impacts | Stakeholder Issues | Total | Total % | Weighted Total | | | |
| Backup Intake | 3.0 | 3.0 | 6.0 | 100.0% | 45.0% | 2.0 | 3.0 | 1.0 | 2.0 | 8.0 | 66.7% | 30.0% | 2.0 | 3.0 | 2.0 | 7.0 | 77.8% | 7.8% | 82.8% | \$1,554,000 | The ability of Loop Creek to meet system needs is not documented and requires further study |
| Interconnect | 3.0 | 1.0 | 4.0 | 66.7% | 30.0% | 2.2 | 2.5 | 2.7 | 2.3 | 9.7 | 80.8% | 36.4% | 3.0 | 3.0 | 2.0 | 8.0 | 88.9% | 8.9% | 75.3% | \$9,945,000 | The WV American New River WTP has sufficient capacity to provide Kanawha Falls with ADF |
| Treated water storage | 3.0 | 2.0 | 5.0 | 83.3% | 37.5% | 1.6 | 1.5 | 2.3 | 2.7 | 8.1 | 67.5% | 30.4% | 3.0 | 2.5 | 2.0 | 7.5 | 83.3% | 8.3% | 76.2% | \$4,427,000 | Tank would be located on acquired property adjacent to the WTP |
| Raw Water Storage | 3.0 | 2.0 | 5.0 | 83.3% | 37.5% | 2.4 | 3.0 | 2.3 | 2.7 | 10.4 | 86.7% | 39.0% | 3.0 | 2.5 | 2.0 | 7.5 | 83.3% | 8.3% | 84.8% | \$4,427,000 | Tank would be located on acquired property adjacent to the WTP |

Table 5. Alternatives Table

| Criteria | Question | Backup Intake | Feasibility | Interconnect | Feasibility | Treated Water Storage | Feasibility | Raw Water Storage | Feasibility |
|---|--|--|-------------|--|-------------|---|-------------|--|-------------|
| Economic Criteria | | | | | | | | | |
| What is the total current budget year cost to operate and maintain the PWSU (current budget year)? | | \$649,200.00 | | \$649,200.00 | | \$649,200.00 | | \$649,200.00 | |
| O and M Costs | Describe the major O&M cost requirements for the alternative? | Electricity for pumping; maintenance | 3 | labor and materials to maintain pipe line; no pump station | 3 | Electricity for transfer pumps, labor, maintenance; does not included water flushed | 3 | Electricity for transfer pumps, labor, recurring maintenance | 3 |
| | What is the incremental cost (\$/gal) to operate and maintain the alternative? | \$695.00 | 3 | \$520.00 | 3 | \$11,437.00 | 3 | \$13,037.00 | 3 |
| | Cost comparison of the incremental O&M cost to the current budgeted costs (%) | 0.11% | 3 | 0.08% | 3 | 1.76% | 3 | 2.01% | 3 |
| O and M-Feasibility Score | | | 3.0 | | 3.0 | | 3.0 | | 3.0 |
| Describe the capital improvements required to implement the alternative. | | Intake structure and pump station; 6800 ft. of 12" diameter pipe | | 88,000 feet of 10" pipe | | 3 MG ground storage tank and transfer pumps | | 3 MG ground storage tank and transfer pumps | |
| Capital Costs | What is the total capital cost for the alternative? | \$1,554,000 | 3 | \$9,945,000 | 1 | \$4,427,000 | 2 | \$4,427,000 | 2 |
| | What is the annualized capital cost to implement the alternative, including land and easement costs, convenience tap fees, etc. (\$/gal) | \$100,000.00 | 3 | \$641,000.00 | 1 | \$285,000.00 | 2 | \$285,000.00 | 2 |
| | Cost comparison of the alternatives annualized capital cost to the current budgeted costs (%) | 15.40% | 3 | 98.74% | 1 | 43.90% | 2 | 43.90% | 2 |
| Capital Cost-Feasibility Score | | | 3.0 | | 1.0 | | 2.0 | | 2.0 |

Table 5. Alternatives Table (Cont'd)

| Criteria | Question | Backup Intake | Feasibility | Interconnect | Feasibility | Treated Water Storage | Feasibility | Raw Water Storage | Feasibility |
|--------------------------------------|---|--|-------------|-----------------------------|-------------|---|-------------|--|-------------|
| Technical Criteria | | | | | | | | | |
| Permitting | Provide a listing of the expected permits required and the permitting agencies involved in their approval. | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 |
| | What is the timeframe for permit approval for each permit? | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 |
| | Describe the major requirements in obtaining the permits (environmental impact studies, public hearings, etc.) | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 | See Permitting Sub-schedule | 2 |
| | What is the likelihood of successfully obtaining the permits? | There may not be sufficient capacity in Loop Creek to support a permit | 1 | No identified barriers | 2 | Potential for nonrevenue water issues | 1 | No identified barriers | 3 |
| | Does the implementation of the alternative require regulatory exceptions or variances? | None identified | 3 | None identified | 3 | In order to avoid flushing water additional studies may be required to support a variance from the 20% turnover rule | 1 | None Identified | 3 |
| Permitting-Feasibility Score | | | 2.0 | | 2.2 | | 1.6 | | 2.4 |
| Flexibility | Will the alternative be needed on a regular basis or only used intermittently? | Intermittent | 3 | Intermittent | 2 | Full time operations | 2 | Full time operations; with ability for intermittent | 3 |
| | How will implementing the alternative affect the PWSU's current method of treating and delivering potable water including meeting Safe Drinking Water Act regulations? (ex. In the case of storage, will the alternative increase the likelihood of disinfection byproducts?) | No changes in treatment or water delivery with the backup source | 3 | No identified changes | 3 | With the requirement to turn over 20% of tank volume the system will be required to flush water during days when demands are low. | 1 | There will be additional operating requirements for the new equipment but the existing treatment process will be minimally affected. | 3 |
| Flexibility-Feasibility Score | | | 3.0 | | 2.5 | | 1.5 | | 3.0 |

Table 5. Alternatives Table (Cont'd)

| Criteria | Question | Backup Intake | Feasibility | Interconnect | Feasibility | Treated Water Storage | Feasibility | Raw Water Storage | Feasibility |
|---|--|--|-------------|--|-------------|---|-------------|---|-------------|
| Resilience | Will the alternative provide any advantages or disadvantages to meeting seasonal changes in demand? | There may not be sufficient capacity in Loop Creek to support a permit | 1 | Yes. Interconnect will provide back up in other emergency situations | 3 | Yes; only short term | 2 | Yes; only short term | 2 |
| | How resistant will the alternative be to extreme weather conditions such as drought and flooding? | There may not be sufficient capacity in Loop Creek to support a permit | 1 | May act as an additional source of supply | 2 | Yes; only short term | 2 | Yes; only short term | 2 |
| | Will the alternative be expandable to meet the growing needs of the service area? | There may not be sufficient capacity in Loop Creek to support a permit | 1 | Yes | 3 | Yes | 3 | Yes | 3 |
| Resilience-Feasibility Score | | | 1.0 | | 2.7 | | 2.3 | | 2.3 |
| Institutional Requirements | Identify any agreements or other legal instruments with governmental entities, private institutions or other PWSU required to implement the alternative. | None identified | 2 | Emergency Usage agreement with WV American at the New River WTP | 2 | None identified | 3 | None Identified | 3 |
| | Are any development/planning restrictions in place that can act as a barrier to the implementation of the alternative? | None identified | 2 | None Identified | 3 | None identified | 3 | None Identified | 3 |
| | Identify potential land acquisitions and easements requirements. | Easement and/or property purchase for intake and pump stations | 2 | Easement and/or property purchase for pump station. | 2 | The tank site would need to be acquired from its current owner | 2 | The tank site would need to be acquired from its current owner. | 2 |
| Institutional Requirements-Feasibility Score | | | 2.0 | | 2.3 | | 2.7 | | 2.7 |
| Environmental Criteria | | | | | | | | | |
| Environmental Impacts | Identify any environmentally protected areas or habitats that might be impacted by the alternative. | Intake structure is likely to require surveys for T&E species | 2 | None identified | 3 | None identified | 3 | None Identified | 3 |
| Environmental Impacts-Feasibility Score | | | 2.0 | | 3.0 | | 3.0 | | 3.0 |
| Aesthetic Impacts | Identify any visual or noise issues caused by the alternative that may affect local land uses? | None identified | 3 | None identified | 3 | The storage tank would be a large structure in an area with few comparably sized structures | 2 | The storage tank would be a large structure in an area with few comparably sized structures | 2 |
| | Identify any mitigation measures that will be required to address aesthetic impacts? | None identified | 3 | None identified | 3 | None identified | 3 | None identified | 3 |
| Aesthetic Impacts-Feasibility Score | | | 3.0 | | 3.0 | | 2.5 | | 2.5 |

Table 5. Alternatives Table (Cont'd)

| Criteria | Question | Backup Intake | Feasibility | Interconnect | Feasibility | Treated Water Storage | Feasibility | Raw Water Storage | Feasibility |
|---|---|---|-------------|---|-------------|--|-------------|--|-------------|
| Stakeholder Issues | Identify the potential stakeholders affected by the alternative. | See Stakeholder Sub-schedule | 2 | See Stakeholder Sub-schedule | 2 | See Stakeholder Sub-schedule | 2 | See Stakeholder Sub-schedule | 2 |
| | Identify the potential issues with stakeholders for and against the alternative. | See Stakeholder Sub-schedule | 2 | See Stakeholder Sub-schedule | 2 | See Stakeholder Sub-schedule | 2 | See Stakeholder Sub-schedule | 2 |
| | Will stakeholder concerns represent a significant barrier to implementation (or assistance) of the alternative? | Possibly from an environmental perspective | 2 | No | 2 | No | 2 | No | 2 |
| Stakeholder Issues-Feasibility Score | | | 2.0 | | 2.0 | | 2.0 | | 2.0 |
| Comments | | The ability of Loop Creek to meet system needs is not documented and requires further study | | The West Virginia American New River WTP has sufficient capacity to provide Wilderness with ADF | | Tank would be located on acquired property adjacent to the WTP | | Tank would be located on acquired property adjacent to the WTP | |

Table 6. Permitting Sub-Schedule

| Permits Required | | | | | | | |
|-------------------------|-----------------|----------------|--------------|-------------------|-----------------------|-------|-------|
| Agency | Permit | Back up Intake | Interconnect | Raw Water Storage | Treated Water Storage | Other | Notes |
| WV Bureau Public Health | Construction | yes | yes | yes | yes | | |
| USACOE ⁽¹⁾ | 404 Permit | yes | no | no | no | | |
| Local/State Road Agency | ROW Utilization | yes | yes | no | no | | |

(1) US Army Corps of Engineers

| Application Period Duration | | | | | | | |
|-----------------------------|-----------------|----------------|--------------|-------------------|-----------------------|-------|-------|
| Agency | Permit | Back up Intake | Interconnect | Raw Water Storage | Treated Water Storage | Other | Notes |
| WV Bureau Public Health | Construction | 90 days | 90 days | 90 days | 90 days | | |
| USACOE | 404 Permit | 180 days | NA | NA | NA | | |
| Local/State Road Agency | ROW Utilization | 90 days | 90 days | NA | NA | | |

| Application Requirements | | | | | | | |
|--------------------------|-----------------|---|---|---|---|-------|-------|
| Agency | Permit | Back up Intake | Interconnect | Raw Water Storage | Treated Water Storage | Other | Notes |
| WV Bureau Public Health | Construction | Engineers Report; Construction Drawings; Specifications | Engineers Report; Construction Drawings; Specifications | Engineers Report; Construction Drawings; Specifications | Engineers Report; Construction Drawings; Specifications | | |
| USACOE | 404 Permit | Construction Drawings; Construction Plan | NA | NA | NA | | |
| Local/State Road Agency | ROW Utilization | Construction Drawings | Construction Drawings | NA | NA | | |

| Other Considerations | | | | | | | |
|-------------------------|-----------------|--|-----------------|-------------------|-----------------------|-------|-------|
| Agency | Permit | Back up Intake | Interconnect | Raw Water Storage | Treated Water Storage | Other | Notes |
| WV Bureau Public Health | Construction | Need to document the ability of Loop Creek to meet capacity requirements | | | | | |
| USACOE | 404 Permit | | | | | | |
| Local/State Road Agency | ROW Utilization | | Bridge crossing | | | | |

Table 7. Stakeholders Sub-Schedule

| List concerns for each alternative by stakeholder | | | | | | |
|---|---|--|---|---|-------|--|
| Stakeholder Group | Back up Intake | Interconnect | Raw Water Storage | Treated Water Storage | Other | Notes |
| Residential Customers | Cost impacts; Improved protection from contamination | Cost impacts; Improved protection from contamination | Aesthetic concerns; Cost impacts; Improved protection from contamination | Aesthetic concerns; Cost impacts; Improved protection from contamination | | Neutral response |
| System Owner | Additional operations; Cost impacts | Additional operations; Cost impacts | Additional operations; Cost impacts | Operational issue with storage turnover; Cost impacts | | Positive to meet regulations and improve service; Negative for treated water storage |
| Industrial/Commercial Customers | Cost impacts; Improved service and protection from contamination | Cost impacts; Improved service and protection from contamination | Cost impacts; Improved service and protection from contamination | Cost impacts; Improved service and protection from contamination | | Neutral to positive response; less sensitive to costs over improved service |
| Environmental Interest Groups | Minor | Minor | Minor | Minor | | Average to negative response |

CONCLUSION

Based on the analysis and findings presented Tetra Tech offers the following conclusions:

1. The storage in the Kanawha Falls system can support 1.68 days of average day demand system-wide. Given the configuration of the distribution system it is likely the tanks work independently and those tanks at the higher elevations will likely empty first if the plant were shut down.
2. Based on the scoring system, raw water storage and a backup intake on Loop Creek are the most feasible alternatives and should be considered for further analysis. **Figures 2 and 3** present conceptual sketches of the alternatives and **Tables 8 and 9** present details on the opinion of capital costs.




Figure 2. Kanawha Falls PSD Raw Water Storage Conceptual Drawing




Figure 3. Kanawha Falls PSD Backup Intake Conceptual Drawing

Table 8. Raw Water Storage – Opinion of Cost

| Facility Description/Capital Cost | | | | |
|--|----------|------|--|--------------------|
| Item | Quantity | Unit | Unit Cost | Total Cost |
| Tank/Reservoir | 1 | EA | \$2,331,375 | \$2,331,375 |
| Raw Water Transfer Pump | 3 | EA | \$20,000 | \$60,000 |
| Raw Water Intake Pump | 3 | EA | \$100,000 | \$300,000 |
| Pre-cast concrete vault for pumps and valves | 1 | EA | \$100,000 | \$100,000 |
| Electrical & Controls | 1 | EA | 10% PS costs | \$46,000 |
| Piping from wet well to tank | 256 | FT | \$92 | \$23,552 |
| Piping from tank to treatment plant | 259 | FT | \$92 | \$23,828 |
| Site Work | 1 | LS | \$120,000 | \$120,000 |
| | | | Subtotal | \$3,004,755 |
| | | | Contingency @ 30% | \$901,427 |
| | | | Eng. Permit, etc. @ 15% | \$450,713 |
| | | | Land | \$70,000 |
| | | | Total Raw Water Storage Capital Costs | \$4,426,895 |

Table 9. Backup Intake– Opinion of Cost

| Facility Description/Capital Cost | | | | |
|---|----------|------|--|--------------------|
| Item | Quantity | Unit | Unit Cost | Total Cost |
| Intake Screen 12" | 1 | EA | \$4,000 | \$2,000 |
| Flow control/Sluice gate | 1 | EA | \$20,000 | \$2,000 |
| Intake Piping - 12" RCP | 50 | FT | \$137 | \$6,850 |
| Piping to plant - 12" DIP (hanging from bridge) | 1237 | FT | \$138 | \$170,706 |
| Piping to plant - 12" DIP | 5567 | FT | \$92 | \$512,164 |
| Raw Water Intake Pumps | 2 | EA | \$100,000 | \$200,000 |
| Pre-Cast Vault for raw water pump station | 1 | EA | \$100,000 | \$100,000 |
| Electrical & Controls | 1 | EA | 10% PS costs | \$30,000 |
| Site Work | 1 | LS | \$50,000 | \$50,000 |
| | | | Subtotal | \$1,073,720 |
| | | | Contingency @ 30% | \$322,116 |
| | | | Eng. Permit, etc. @ 15% | \$161,058 |
| | | | Land Acquisition and Easements | \$370,528 |
| | | | Total Backup Intake Capital Costs | \$1,556,894 |

APPENDIX E. SUPPORTING DOCUMENTATION

E-1. Protection Team Meeting

Date: 4/6/2016

Location: Gauley Bridge Town Hall, Gauley Bridge, WV

Participants: Chief Operator Carl King, Rick Wagner, Roger Wagner, Kim Houghton, Damon Runyon, and Tetra Tech representative Russell Myers

- On Wednesday April 6, 2016, the Source Water Protection Team for Kanawha Falls PSD met at the Kanawha Falls PSD office to discuss the draft of the updated Source Water Protection Plan. All suggested members were in attendance except Chris Farrish, who will be involved in future planning efforts whenever possible.
- Russell presented the draft plan and mapping information to the team and they discussed the potential contaminants as well as some of their priority sites.
 - Utility staff recommended that the old Exxon storage facility that is just downstream of the Kanawha Falls intake should be examined more closely to ensure that it was closed down properly. They are unsure that all the fuels and chemicals on site were disposed of properly, and report that there were both aboveground and underground tanks on site. This would not be an issue for KF but could be for downstream systems like Armstrong PSD.
 - Rick has been wanting to reach out to local recreational users of the Kanawha River to let them know more about source water protection and how they can help protect it. He would like to tell them how to keep an eye out for potential sources of contamination when they are out fishing or riding four wheelers. He asked that TT provide a brochure that can be handed out to users to let them know what to look out for.
 - Rick requested a copy of a flyer that he can use to post around town to solicit comments and questions about the SWPP. Include information in the flyer about alerting staff about potential problems.
 - Utility staff report that the nearby railways are their primary contamination concern. There is no way for staff to know what is being transported or how often. Rick suggested that he could reach out to Norfolk Southern to get more information about these shipments and what kinds of materials they typically transport.
 - The hydroelectric facility upstream, Hawks Nest Hydro, is a potential source of contamination. Incidents have occurred in the past but the facility has very reliable communication with the water plants downstream and always alerts them of any potential problems. They feel that this threat is managed as well as possible. In addition, the Brookfield site is in the process of installing a water treatment/separation system on site, which should further prevent any contamination.
 - The DOH garage that is located upstream manages their road treatment materials and fuels well and staff feel that there is no threat from this site. It can be removed from the priorities list.
 - The upstream sewer system is managed by KF and operators are in constant contact with the water treatment plant.
 - Rick requested a list of examples of free alert systems that he could use to communicate with customers for free. They currently primarily use local radio, TV, and Fayette Co. 911.

E-2. List of Regulated Databases

In addition to PSSC that have been identified by the WVBPH and local efforts, water systems should consider data available from regulatory agencies, such as the US Environmental Protection Agency (USEPA) and the WV Department of Environmental Protection (WVDEP). The follow presents examples of regulatory program databases that should be considered.

USEPA

CERCLIS:

The Superfund program was created by the Comprehensive Environmental Response, Compensation, and Liability Act, amended by the Superfund Amendments and Reauthorization Act. The acts established authority for the government to respond to the release/threat of release of hazardous wastes, including cleanup and enforcement actions. Long-term cleanups at National Priority List sites last more than a year while short term /emergency cleanups are usually completed in less than a year. CERCLIS is a database used by the USEPA to track activities conducted under its Superfund program. CERCLIS contains data on potentially hazardous waste sites that have been reported to the USEPA. Sites are investigated because of a potential for releasing hazardous substances into the environment are added to the CERCLIS inventory. USEPA learns of these sites through notification by the owner, citizen complaints, state and local government identification, and investigations by USEPA programs other than Superfund. Specific information is tracked for each individual site.

NPDES:

The National Pollutant Discharge Elimination System (NPDES) database identifies facilities permitted for the operation of point source discharges to surface waters in accordance with the requirements of Section 402 of the Federal Water Pollution Control Act. Point sources are discrete conveyances such as pipes or man-made ditches. Industrial, municipal, and other facilities must obtain permits if their discharges go directly to surface waters. The NPDES permit program controls water pollution by regulating point sources that discharge pollutants into public waters.

RCRA:

This database has records for all hazardous waste, generators, and transporters as defined by the Resource Conservation Recovery Act (RCRA). Hazardous waste as defined by RCRA is waste material that exhibits ignitability, corrosivity, reactivity, or toxicity. Hazardous waste comes in many shapes and forms. Chemical, metal, and furniture manufacturing are some examples of processes that create hazardous waste. RCRA tightly regulates all hazardous waste from "cradle to grave" (i.e., from manufacture to disposal).

TRI:

The Toxics Release Inventory (TRI) is a publicly available USEPA database that contains information on toxic chemical releases and other waste management activities reported annually by certain covered industry groups as well as federal facilities. This inventory was established under the Emergency Planning and Community Right-to-Know Act of 1986 (EPCRA) and expanded by the Pollution Prevention Act of 1990.

WVDEP

Abandoned Mine Sites:

Abandoned mine features compiled by the Office of Abandoned Mine Lands and Reclamation (AMLR) of the WVDEP. The AMLR eliminates damage that occurred from mining operations prior to August 3, 1977 and is funded by the AML fund. It corrects hazardous conditions and reclaims abandoned and

forfeited mine sites. Typical AML features include high walls, portals, refuse piles, and mining structures such as tipples.

AST:

Above Ground Storage Tanks are regulated by the WVDEP and are subject to specific standards. Any facility using an AST should contact the WVDEP Water and Waste Management office for current requirements and further advice at 304-926-0495 or

<http://www.dep.wv.gov/WWE/abovegroundstoragetanks/Pages/default.aspx> .

Coal Dams:

Point and polygonal mining related impoundments regulated by the WVDEP Division of Mining and Reclamation (DMR).

LUST:

The WVDEP became the lead agency for administering the Leaking Underground Storage Tank (LUST) Program with the USEPA's authorization in September 1997. Since then, the WVDEP has overseen the cleanup of released regulated substances, primarily petroleum products. Such releases can originate from overfilling, spilling, or leaking tanks and piping. To report a release from an underground storage tank system, contact the Office of Environmental Remediation at 304-238-1220, ext. 3506. After hours releases should be reported to the statewide emergency spill line at 800-642-3074.

Solid Waste Facilities:

Municipal and non-municipal waste landfills and waste transfers stations are regulated by the WVDEP Division of Waste Management.

Oil and Gas Wells:

The Office of Oil and Gas maintains records on active and inactive oil and gas wells. It also manages the Abandoned Well Plugging and Reclamation Program.

UIC:

The Underground Injection Control (UIC) program is designed to ensure that fluids injected underground will not endanger drinking water sources. The Division of Water and Waste Management regulates Class 5 wells. These wells include agriculture drainage wells, improved sinkholes, industrial disposal wells, storm water wells and septic systems that have the capacity to serve 20 or more people. The following state codes address UIC regulations; 47CSR9, 47CSR13 and 47CSR55. The Division of Mining and Reclamation oversees all mining UIC permits.

UST:

The purpose of the Underground Storage Tank (UST) Section is to regulate underground storage tanks that contain petroleum or hazardous substances to determine compliance with state rules and federal regulations. West Virginia has had full program approval from USEPA since February 1988

KANAWHA FALLS PSD

2016 Source Water Protection Plan



TETRA TECH

Kanawha Falls PSD has updated their Source Water Protection Plan (SWPP) in cooperation with the West Virginia Bureau for Public Health and Tetra Tech. This plan was developed according to guidelines in WV code. The intent of the plan is to identify strategies to minimize potential threats to source water and prepare for spills or other emergencies that could affect water service.

Kanawha Falls PSD is a state regulated public utility located near Gauley Bridge, WV that uses raw water from the Kanawha River. Water treatment processes include coagulation, sedimentation, filtration, disinfection, and fluoridation.

Source Water Protection Plan Requirements

- Complete Source Water Protection Plan, if utility's source is surface water or groundwater influenced by surface water
- Engage local government, health department, emergency planners, and affected residents
- Update every 3 years

Source Water Protection Plan Includes:

- System Information
- Protection Team
- Source Water Protection Area Delineations
- Potential Sources of Significant Contamination
- Plan to Manage Prioritized Concerns
- Education and Outreach Activities
- Contingency Plan Information
- Single Source Feasibility Study
- Communication Plan

Protection Team Information

- Kanawha Falls PSD has formed a protection team to contribute to the SWPP that includes:
 - Utility staff, local government, emergency responders, health department, interested public representatives.

Kanawha Falls PSD System Information

- 1,041 customers directly served (approx. 2,602 people) in Fayette County

Contact:
 Utility Manager – Rick Wagner
 PSD Office Phone: 304-632-1633
 Tetra Tech, Inc. – Russell Myers
 Phone: 304-414-0054
 Email: Russell.Myers@tetratech.com

- Sells water to Gauley River PSD, serving 800 customers indirectly
- Serves approx. 6,300 people directly and indirectly.
- Production Capacity = 1,440,000 gal./day
- Average Production = 736,000 gal./day
- 6 treated water storage tanks
- Total treated water storage capacity = 1,235,000 gal. or roughly 1.7 days of storage at average usage

Source Water Protection Areas

- The watershed delineation area for Armstrong PSD covers approximately 8,384 square miles in the Upper Kanawha River watershed.
- Zone of Critical Concern (ZCC) = 14,325 acres
- Zone of Peripheral Concern (ZPC) = 69,199 acres

| Kanawha Falls PSD – PSSC Summary | | | | | | |
|-----------------------------------|------------|------------|------------|-------------|--------------|---------------|
| PSSC Layer | In ZCC | Around ZCC | In ZPC | Around ZPC | In Watershed | Total Records |
| Above Ground Storage Tanks | 54 | 57 | 89 | 221 | 1426 | 1874 |
| AMI Points | 14 | 3 | 62 | 121 | 395 | 595 |
| Bond Forfeiture | 0 | 3 | 15 | 41 | 238 | 297 |
| Closed Landfills | 0 | 0 | 0 | 1 | 1 | 2 |
| Field Verified PSSCs | 23 | 4 | 53 | 34 | 940 | 1054 |
| Landfill Monitoring Wells | 0 | 0 | 0 | 4 | 0 | 4 |
| Leaking Underground Storage Tanks | 2 | 0 | 1 | 4 | 131 | 138 |
| Mining Outlets | 38 | 86 | 146 | 482 | 3141 | 3893 |
| NPDES Permits | 11 | 7 | 108 | 163 | 2424 | 2713 |
| Oil/Gas Wells | 140 | 165 | 334 | 505 | 1797 | 2941 |
| Points of Interest | 0 | 0 | 0 | 0 | 25 | 25 |
| USEPA Regulated Sites | 23 | 6 | 74 | 116 | 2423 | 2642 |
| Virginia PSSCs | 0 | 0 | 0 | 0 | 153 | 153 |
| Volunteer Remediation | 0 | 0 | 0 | 2 | 24 | 26 |
| Coal Refuse Sites | 0 | 0 | 2 | 2 | 34 | 38 |
| Total | 305 | 331 | 884 | 1696 | 13152 | 16368 |

Priority Concerns for Mount Hope

- WV Division of Highways garage
- Barge, railroad, and highway traffic
- Public wastewater facilities


Management Plan, Education/Outreach Strategies

- Monitor Source Water Protection Area
- Regularly coordinate with emergency responders
- Communicate with managers at the Division of Highways garage and with companies that transport hazardous materials through the ZCC.
- Coordinate with personnel at upstream wastewater facilities regarding overflows and releases.

Communication Plan

- Kanawha Falls PSD will contact affected residents within 30 minutes of determining a threat to human health using:
 - word of mouth
 - radio broadcasts
 - posted notices
 - local newspapers

Monitor local media for status updates once this notification has been made.



TIERS Reporting System

| | |
|------------------------------|--|
| A Announcement | The water system announces that an incident or event may pose a threat to public health and safety. Additional information will be provided as it becomes available. |
| B Boil Water Advisory | Water system users are advised to boil any water to be used for drinking or cooking, due to possible microbial contamination. This system operator will notify users when the boil water advisory is lifted. |
| C Cannot Drink | System users should not drink or cook with the water until further notice. The water can still be used for showering, bathing, cleaning, and other tasks. |
| D Do Not Use | The water should only be used for flushing commodes and fire protection until further notice. More information on this notice will be provided as soon as it is available. |
| E Emergency | The water should not be used for any purpose until further notice. More information on this notice will be provided as soon as it is available. |

Confidentiality Statement

I have reviewed and understand the requirements to maintain PSSC data in a confidential manner (64CSR3). While I may discuss PSSCs in general terms, I understand that I am not permitted to release exact locations, characteristics or quantities of contaminants to the general public.

Kanawha Falls PSD Designees:

| Name | Title | Phone | Email | Signature | Date |
|----------------|----------------|--------------|---------------------------|----------------|--------|
| Richard Wagner | Gen. Mng'r. | 304-632-1633 | | Richard Wagner | 4-6-16 |
| Roger Wagner | Chairman | 304-640-2101 | rwagner@glbssm.com | Will Wagner | 11 |
| Carl King | Chief Operator | 304-779-2600 | | Carl King | 4-6-16 |
| Kim Houghton | Town Recorder | | KIM HOUGHTON & SUNDEN INC | Kim Houghton | 4-6-16 |
| Damon Runyon | Fire Chief | 304-632-1810 | damon_47@yahoo.com | Damon Runyon | 4-6-16 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

GET INVOLVED IN SOURCE WATER PROTECTION

Kanawha Falls PSD has developed a Source Water Protection Plan to comply with recent state legislation regarding drinking water. All public water utilities that use surface water sources must complete and submit a plan by July 1, 2016.



-Source Water Protection Plans are valuable tools to help any public water system plan for and manage water emergencies. Development of these plans relies on the involvement of water utility personnel, local government officials, emergency managers, health department representatives, and local community leaders.

-Your water system is committed to informing and engaging the public during development and implementation of this plan. You are invited to contact or visit the Kanawha Falls PSD office to review the draft of the plan before it is submitted. Now is your chance to provide your input.

To get involved in the planning process,
please contact Kanawha Falls PSD no later
than April 29, 2016

Phone: 304-632-1633
Email: kfpsd_12@yahoo.com

*Do your part to keep
contaminants out of our
children's source water!*



Contaminants

Cleaning Products

Automotive Products

Fuel Oil

Furniture Strippers

Oil-based Paints

Sewage

Lawn and Garden Products

Sediments

Pharmaceuticals

Source Water Links

www.wvdhhr.org/oehs/eed/swap/
www.epa.gov/safewater/index.html
www.epa.gov/watersense/
http://orsanco.org

For Kids

www.epa.gov/safewater/kids/index.html
www.epa.gov/watersense/kids/index.html
www.groundwater.org/kids/



Contacts

WV Department of Health and Human Resources
Source Water Assessment and Protection Program
350 Capitol Street, Room 313
Charleston, WV 25301-3713
phone: (304) 558-2981
fax: (304) 558-4322
e-mail: EEDSourceWaterProtection@wv.gov

*Do Your Part
Protect Your
Source Water
Protect Your
Health*



TETRA TECH

Prepared by Tetra Tech

*In cooperation with the WVDHHR Source Water
Assessment and Protection Program*

Drinking water is essential for life. Learn what you can do to protect your drinking water sources.

Making choices to protect and conserve the source of your drinking water will help keep you, your family, and neighbors safe and healthy now and in the future.



Do Your Part to Protect Source Water

- ✓ Recycle used oil and other automotive products at a service center. Don't pour them on the ground or down storm drains. Storm drains can lead directly to your source water.
- ✓ Fix leaks from your automobile and clean up spills.
- ✓ Apply fertilizers and pesticides as directed. Consider natural alternatives to chemicals.
- ✓ Don't flush pharmaceuticals. Dispose by mixing with coffee grounds or kitty litter, sealing in a container, and placing in the trash. Organize a collection day with a pharmacy and local police department.
- ✓ Take unwanted household chemical waste, such as cleaners, oils, and paints to proper waste collection sites. Don't dump down your sink, toilet, or storm drains. Consider organizing a collection day in your community.
- ✓ Check for leaks at heating fuel tanks and install pads to catch accidental leaks or spills.
- ✓ Report unused water wells to your utility or WVDHHR.
- ✓ Inspect your septic system regularly and pump every 5-10 years.



Do Your Part to Conserve Source Water

- ✓ Turn off the water when you brush your teeth and take shorter showers.
- ✓ Wash full loads of clothes and dishes.
- ✓ Don't use your toilet to flush trash.
- ✓ Fix leaking faucets, toilets, and lines. Consider installing toilets, faucets, and appliances designed to save water.
- ✓ Water your lawn and garden in the morning. Consider installing a rain barrel at your downspouts to collect rain to water your lawn and garden, instead of using treated water.
- ✓ Use native plants in landscape that don't need extra watering. Use mulch to hold moisture.
- ✓ Don't let your garden hose run when washing your car.
- ✓ Don't panic if you are asked to conserve during a drought. Your utility will respond to water shortages based on your normal water use. Running extra water in your home during a drought will make it more difficult to respond to the water shortage.



Conserving water saves on your monthly bill now. Protecting your source water will save on treatment costs later.